

RFT 21-134 Renovations – Burlington Central HS

The following, issued by the Halton District School Board May 13, 2021, shall be incorporated in the specifications and shall form part of the proposal document for the above.

ATTACHED:

- Architectural Addendum #3 dated May 13, 2021 provided Snyder Architects Inc. - 1 page

RECEIPT OF ADDENDA MUST BE ACKNOWLEDGED ON THE FORM OF TENDER.

PAGE 1 OF 2
END OF ADDENDUM 4

ARCHITECTURAL ADDENDUM No.3

Project	Burlington Central HS Renovations	Date of Issue	May 13, 2021
Project No.	2005	File	7.1.03Addenda
Owner	Halton District School Board	Contract(s)	All contracts

This Addendum forms part of the Contract Documents and amends the original Drawings and Specifications and Addenda issued to date, as noted below.

Ensure all parties submitting bids are aware of all items included in this Addendum. Read, interpret and coordinate the items contained herein with the Contract Documents and include all related costs as part of the Bid Price. **Acknowledge receipt of this Addendum by inserting its number on the Bid Form.** Failure to do so may subject bidder to disqualification.

This Addendum consists of 1 page

	Project Manual
1.	08 51 13 Aluminum Windows 2.6.6.2 Provide 'collapsible crank' type operator in lieu of the specified 'knob' type Windows to meet the OBC requirements related to 'Guards' including 'Loads on Guards'
2.	Manual shades Manual shades to be provided at glazing at all new windows and all hollow metal screens (S01 to S05).
	Architectural Drawings
3	Drawing A200-D (dwg not re-issued) Note D5: Grinding of adhesive residue left behind is included in scope of work
4	Drawing A800 (dwg not re-issued) Refer to note ' all headers and jambs to receive aluminum trim with return' – add 'trim to be min 150mm wide'
5	Drawing A801 (dwg not re-issued) 3/A801: revise window sill depth to 50mm from 38mm
6	Clarification regarding dry walls: GB to stop 10mm short of floor to avoid moisture related issues
7	Product Substitution 08 80 00 Glazing Fire-rated glazing from SaftiFirst is acceptable as long as it complies with the requirements noted in the bid documents for the respective fire-rated glass.

END OF ADDENDUM 03