ADDENDUM 4

April 19, 2022 Page 1 of 2

MECHANICAL

Refer to attached Addendum No. 2 with issued by RM Engineering Inc. dated April 19, 2022 for sink and faucet specification (1 page).

End of Addendum



499 Brookside Drive Oakville, On. L6K 1R4 Tel: (905) 617-4804

ADDENDUM No. 2

DATE: April 19, 2022

PROJECT TITLE: Holy Cross Parish Office & Kitchen Renovation

PROJECT LOCATION: 1883 King Street East, Hamilton, ON, L8K 1V9

PROJECT NUMBER: 20004

SUBJECT: Kitchen Sink & Faucet Specification

Contractor is hereby instructed with the following changes/clarifications to the contract documents as described below. All materials and workmanship are to be as described in the contract documents unless stated otherwise.

1.0 Mechanical Drawings:

1.1 Mechanical Drawing - M5

 Kitchen Sink & Faucet Items #8 Specification to be as follows: Koolmore - SA14161112L3
 One compartment stainless steel hand sink
 High-grade heavy duty 18 gauge 304 type stainless steel
 14" x 16" X 11" bowl size 29 L x 21 W x 44. 5 H overall dimensions
 Adjustable 1 1/2 bullet feet

Chicago Faucet - 540-LDABCP
Rear sink / Wall Mounted dual supply
8" Body, Adjustable Arms 7-1/4" - 8-3/4"
E3AB - 2.2 GPM (8.3 L/min) Pressure Compensating Softflo Aerator
369-PR - Vandal Proof 2-3/8" Lever Handle, Sixteen-Point Tapered Broach
XTAB - Quaturn Compression Operating Cartridge
GAB - 3/8" Offset Inlet Supply Arm
2 5/16" Diameter Slip Flange
Chrome Plate Finish

Prepared by: Jure Mandic, P. Eng.,

RM Engineering Inc.
June Monulai