



Addendum #3

Bid Opportunity: 7274-RW-22

**Forest Heights Collegiate Institute – Family Studies Renovation,
Partial Window & Brick Replacement, Column Repair, Asphalt
Replacement & Barrier Free Washroom**

Closing Date: Thursday, April 14, 2022 2:00 PM

The following issued by the Board shall form part of the Bid / Proposal Solicitation document. The revisions and additions noted herein along with any attachments shall be read in conjunction with all other related documents. This Addendum shall, take precedence over the previously issued documents where differences occur. Receipt of this addendum must be acknowledged in the Bidding System, bids&tenders.

If you have already submitted a Bid / Proposal, it will be automatically withdrawn as a result of this addendum. You must resubmit the Bid / Proposal acknowledging all addenda and revising your Bid / Proposal to comply with all addenda.

Section 1 – Board Initiated Changes

ITEM 1: Bid Closing Date / Time

Change Bid closing from no later than 2:00 PM on Wednesday, April 13, 2022, to
no later than 2:00 PM on Thursday, April 14, 2022.

Section 2 – Vendor Questions

Question 1:

Is there a Geo report or environmental assessment for this project?

Answer 1:

No, there is not.

Question 2:

We are asking for an extension on this project.

Answer 2:

Refer to Section 1 / Board Initiated Changes in this Addendum

Question 3:

As per section 01 21 00 Allowances, the sum of individual Allowances given in the Schedule is \$61,000.00 whereas the total amount written in section is \$55,000.00. Please clarify.

Answer 3:

Refer to Section 01 21 00, item 1.4 and change Total of All allowances to read: \$61,000.00

Question 4:

Has the soil on site been tested to meet reg. 406/19 (on-site and excess soil management)? Can we assume for pricing purposes that the material meets table 1?

Answer 4:

Soil has not been tested. Assume, for pricing purposes, that material meets the requirements of Table 1.

Section 3 – Clarification / Initiated by the Consultant

The information below provides additional clarification and does not change the Scope or intent of the bid document.

ITEM 1: Clarification to Architectural Specifications

Section 10650 Operable Glass Partitions

- .1 Refer to 2.1.1.1 Partition Panels and add the following new items 5 and 6.

- .5 Panel Finishes:**

- Provide top, side, and bottom rails with the following finishes:

- .1 New Family Studies 6-20: Clear anodized aluminum
 - .2 New Family Studies 6-22: Clear anodized aluminum

- .6 Acoustical Ratings:**

- Acoustical ratings of panels to achieve the following Sound Transmission Class of minimum STC when tested in accordance with ASTM E90 and classified in accordance with ASTM E413:

- .1 New Family Studies 6-20: 26 STC
 - .2 New Family Studies 6-22: 26 STC

- End of Addendum #3 -