

**2022-PW-16-1**

**Title: Town Hall Addition**

**Location: Town of Pelham**

**ADDENDUM NO. 3**

**I DIRECTIVE**

This Addendum shall form an integral part of the plans and specifications for the above project and shall be read in conjunction therewith. This Addendum shall, however, take precedence over all requirements of the previously issued drawings and specifications with which it may prove to be at variance, unless otherwise clarified by the Engineer.

This addendum must be signed by the Tenderer in the appropriate space and must be uploaded as a PDF to the bid document with submission.

**II QUESTIONS**

**Question 1:**


The structural specifications require galvanized finish for exposed steel. On drawing A4.50, there is a note pointing to the clock tower steel structure specifying galvanized finish. The clock tower is finished with EIFS stucco system and therefore is not "exposed". Can you please clarify if galvanizing is required for the clock tower frame? If so, the cost would be significantly higher for the clock tower frame.

**Answer 1: Galvanizing for the steel tower is NOT required**

**END OF ADDENDUM NO. 3**

Date Issued: July 5, 2022

Signature:

  
\_\_\_\_\_  
Jason Marr, P.Eng  
Director of Public Works

**THE TENDERER SHALL ADJUST HIS BID PRICE ACCORDING TO THE CHANGES SPECIFIED IN THIS ADDENDUM.**