



**Waterloo Catholic
District School Board**

ADDENDUM # 001

**Monsignor Doyle CSS Renovation
185 Myers Rd, Cambridge. ON**

RFT No. 2024-01

17/21 Project No 2330

Documents prepared by:

17|21 architects inc.
1065 Valetta Street, Suite A
London, Ontario
N6H 2Z9

Issue Date:

Friday, 01 March 2024

This addendum forms part of the Contract Documents and amends the original drawings dated February 15, 2024 marked as ISSUED FOR TENDER and specifications dated February 15, 2024

TABLE OF CONTENTS

ADDENDUM # 1 (Including cover)	3 Page(s)
Picture for Question#2	2 Page(s)
List of General Contractors – Non-mandatory Site Visit	1 Page(s)
Section 00 71 00 - Supplementary Form of Tender	12 Page(s)
Schedule of Finish Hardware	77 Page(s)
Addendum No 01 for Callidus Engineering	1 Page(s)

TOTAL PAGE COUNT FOR THIS ADDENDUM	96 Page(s)
---	-------------------

PART A- GENERAL

1- Attached is a list of the General Contractors and trades that went to the non-mandatory Site Visit.

2- Questions:

Question #1:

As per section 09645 specification Canadian Martyrs catholic School, Page 1 Preparation. Requesting certification. I have been advised by Ardex that there is only one company in Ontario that has "Level master Elite Certification" We are however "Certified Ardex installer" and have had the training and certification from Ardex. Can we except that as pre -qualification.

Answer:

Remove "Subcontractors must have Level master Elite Certification", form 1.2 Quality Assurance, .1 Subcontractor Qualifications, Section 09645.

Question #2:

Regarding drawing A104, there are 2 areas of elastomeric membrane flashing work at the bottom of the wall. Do you have any photos? Is there any other work required on the actual wall itself?

Answer:

Pictures attached. No other work is required at this moment.

Question #3:

Regarding the new EF-1 & EF-2, are the existing curbs being reused? If yes, do we need to install new membrane flashing?

Answer:

New curbs as specified in exhaust fan schedule.

Question #4:

On drawing number M2, its states to extend existing 75mm lab exhaust vent and provide guy wire supports. Is the flashing for 75mm vent getting replaced? How many guy wire supports and will a detail be provided.

Answer:

Lab vent flashing won't be replaced, three guy wires required, we won't be detailing it.

PART B- SPECIFICATIONS

1- Section 09650 – Resilient Flooring:

.1 Materials

Delete:

.2 Flooring

.1 ~~Carbon Flooring~~

Add:

.2 Flooring

.1 IQ **OPTIMA** HOMOGENEOUS RESILIENT SHEET & TILE FLOORING. Size: 24" X 24" Tile.

2- Section 09680 - Carpet:

2 **Carpet tile:**

QUICKSHIP – Interface - Aerial, Open air Collection

3- Section 00 71 00 - SUPPLEMENTARY FORM OF TENDER attached.
Refer to Section 1.3 SEPARATE PRICES

4- Attached Finish Hardware Schedule

PART C – ARCHITECTURAL DRAWINGS

RESERVED.

PART D – MECHANICAL / ELECTRICAL DRAWINGS

1- Refer to Addendum No. 01 from Callidus Engineering, attached.

END OF ADDENDUM # 001

PICTURES FOR QUESTION #2:





END

Submit this Supplementary Form of Tender at the close of General Tenders.

1.1 TENDER INFORMATION

TENDER CLOSE: **March 7th, 2024 at 2:00:00pm** local time

SUPPLEMENTAL TENDER FORM CLOSE:

March 7th, 2024 at 4:00:00pm local time.

NAME OF PROJECT: **Monsignor Doyle CSS Renovation**

PROJECT NUMBER: **2024-01**

Submission Email Address: stephen.butterworth@wcdsb.ca

1.2 SUPPLEMENTARY LIST OF SUBCONTRACTORS

- .1 I/We, the undersigned, propose to use the following Subcontractors and/or suppliers to perform work of this Contract, and I/we confirm that all have been investigated to confirm their reliability and competence to carry out the Work in accordance with the Contract Documents; and I/we agree that no changes from this may be made without the express written approval of the Board.

Extra costs to the Contract will not be considered for a Subcontractor/supplier substitution, regardless of the reason, except where a substitution is requested by the Owner.

Site Services _____

Asphalt Paving _____

Masonry _____

Structural Steel _____

Metal Fabrications _____

Cabinetwork _____

Sprayed Fireproofing _____

Roofing _____

Glazing _____

Gypsum Board and Acoustical Ceilings _____

Ceramic Tile _____

Resilient Flooring _____

Painting _____

Whiteboards and Tackboards _____
Gymnasium Equipment _____
Lift for Disabled _____
Electrical _____
Mechanical _____

1.3 SEPARATE PRICES

- .1 Separate Price items do NOT replace or substitute items already in the Bid Documents. Accepted Separate Prices are to be in accordance with Section 002100 (Instructions to Bidders) excluding HST:
- .1 **Separate price #1: Replacement of existing light fixtures in corridors, main office and gymnasium as described in the electrical drawings & specifications.** \$ _____
 - .2 **Separate price #2: Replacement of existing light fixtures in classrooms as described in the electrical drawings & specifications.** \$ _____

1.4 ELECTRICAL UNIT PRICES:

- .1 I/We enclose herewith Unit Prices, exclusive of applicable taxes, which are an integral part of the Bid. Unit prices are, in effect, for the duration of this Project's construction period, unit prices are exclusive of applicable taxes.
- .2 The following unit costs will apply to all additional or deleted work from the Contract and should include their proportionate share of all labour equipment, materials, accessories, profits, overhead and taxes for a job completely installed. Applications of unit prices will be to the net difference of quantities of individual products and materials in each Proposed Change or Change Order.
- .3 The unit prices will be used for additions and deletions. Credit rate for deletions shall be at 80% of original rates listed under sections 1.4, 1.5, 1.6, 1.7, 1.8, 1.9.
- .4 Conduit and Cable:
- Supply and install the following conduit and cables including fastenings, clips, connectors, coupling boxes, etc. as required based on length as shown.

MORE WORK

- .1 25MM EC/3500mm Length \$ _____
- .2 2 #12-12mm C/3500mm Length \$ _____

-
- | | | |
|----|----------------------------|----------|
| .3 | 3 #12-12mm C/3500mm Length | \$ _____ |
| .4 | 2 #10-19mm C/3500mm Length | \$ _____ |
| .5 | 3 #10-19mm C/3500mm Length | \$ _____ |
| .6 | 3 #8- 19mm C/3500mm Length | \$ _____ |
-
- .5 Receptacles:
- Supply and installation of one duplex receptacle, shall include the receptacle box, cover plate, 5000mm of conduit and wiring, including connection to adjacent receptacle and/or outlet box.
- MORE WORK
- | | | |
|----|--|----------|
| .1 | Supply and installation of one duplex receptacle | \$ _____ |
|----|--|----------|
-
- .6 Light Switches
- Supply and installation of light switch shall include the switch box, cover plate, conduit, wiring and connection to box containing the lighting circuit.
- MORE WORK
- | | | |
|----|---|----------|
| .1 | Supply and installation of one 347 volt light switch. | \$ _____ |
|----|---|----------|
-
- .7 Fire Alarm System:
- MORE WORK
- | | | |
|----|--|----------|
| .1 | Supply and installation of one fire alarm pull station, including conduits, wiring and connections to the nearest fire alarm pull station. (Base conduit and wiring on 1500mm length). | \$ _____ |
| .2 | Supply and installation of one fire alarm cone speaker including conduit, wiring and connections to nearest fire alarm cone speaker. (Base conduit and wiring on 1500mm length). | \$ _____ |
-
- .8 Lighting Fixtures:
- Supply and installation of the following lighting fixtures. The supply and installation of lighting fixtures shall include the fixtures, flexible conduit, wiring and connection to nearest outlet box containing 347 and/or 120 volt circuits and the supply and installation of the lamps. (Base conduit and wiring on 4500mm length).
- MORE WORK

.1	Supply and installation of one type 'A' fixture	\$ _____
.2	Supply and installation of one type 'B' fixture	\$ _____
.3	Supply and installation of one type 'C' fixture	\$ _____
.4	Supply and installation of one type 'E' fixture	\$ _____
1.5	LABOUR RATES	

I/We enclose herewith Labour Rates which are an integral part of the Tender. Labour rates are in effect for the duration of this Project's construction period. The Owner is not obligated to accept Labour rates indicated.

.1 Mechanical Labour Rates

Labour at the following rates should be applied for additions or deletions to the work not covered by unit prices. The prices consist of salary, all agreed local union benefits. The rate quoted represents the net cost to the Contractor, exclusive of overhead and profit and applicable taxes.

.1	Plumbing & Drainage Tradesmen	\$ _____ Per Hour
.2	HVAC Piping Tradesman	\$ _____ Per Hour
.3	Insulation Tradesmen	\$ _____ Per Hour
.4	Sheet Metal Tradesmen	
.1	Shop	\$ _____ Per Hour
.2	Field	\$ _____ Per Hour
.5	(Other)	\$ _____ Per Hour
.6	Sprinkler Pipefitter & Installer	\$ _____ Per Hour
.7	Sprinkler Work Office/Engineer	\$ _____ Per Hour

1.6 SPRINKLER SUB-CONTRACTOR CASA MEMBERSHIP

Sprinkler Contractor shall be a paid member, and in good standing at time of Tender, of the Canadian Automatic Sprinkler Association. Attach membership certificate to this Supplementary Form of Tender.

.1 Labour at the following rates shall be applied for additions or deletions to the work not covered by unit prices. The prices consist of salary, all agreed local union benefits. The rate quoted represents the net cost to the Contractor, exclusive of overhead and profit and applicable taxes.

- .1 Journeyman \$ _____ Per Hour
- .2 Foreman \$ _____ Per Hour

1.7 MECHANICAL MANUFACTURERS AND SUPPLIERS:

I/We enclose herewith a list of Manufacturers and Suppliers to the Mechanical Building Services which is an integral part of the Tender. We hereby agree that the Owner may select from any substitutes that we have offered in our Tender. Our Tender Price is based on the equipment/manufacturers indicated hereunder and we hereby agree that we will not alter the indicated equipment/manufacturers unless specifically authorized by the Owner.

I/We, the undersigned, have inserted below proposed substitutions and prices for the Owner's consideration.

I/We agree that:

- .1 all prices submitted take into consideration and allow for changes and adjustments in other work as may be necessary to provide a finished and functional result, unless specifically indicated otherwise;
- .2 alternative prices are for work which is not included in the Tender price listed on Form of Tender but which may be substituted by the Owner for work which is included (no price listed shall mean no change in cost);
- .3 and that the Board reserves the right to accept or reject any of the prices proposed hereunder;
- .4 prices listed hereunder do not include HST

	<u>Product/Equipment Specified</u>	<u>Proposed Substitution</u>	<u>Reduction in Contract Price</u>
.1	_____		\$ _____
.2	_____		\$ _____
.3	_____		\$ _____
.4	_____		\$ _____
.5	_____		\$ _____
.6	_____		\$ _____

Attach additional sheets and supporting documentation, if necessary.

1.8 STANDARDS OF MECHANICAL MATERIALS

BASE BID ITEM	ACCEPTABLE BASIS OF DESIGN	ALTERNATE
Pipe Hangers	Grinnell	Crane, Flamco, Unistrut
Mechanical Grooved Joints	Victaulic	Coupcos, Gruvlok
Unions	Crane	Grinnell, Dart
Expansion Joints	Flexonics	Amtrol, Hydroflex Tube Turn
Gate, Globe & Ball Valve	Crane	Jenkins, Toyo/R+W Kitz
Check Valves	Crane	Jenkins, Toyo/R+W Kitz
Plug Valves	DeZurick	NEO
Circuit Balancing Valves	Tour and Andersson	
Butterfly Valves	Crane	Jenkins, Centerline, Kitz, Toyo
Thermal Insulation	Fiberglas Canada	Manson, Knauf Johns-Manville
Pumps & Circulators (Except as noted)	S.A. Armstrong	ITT Fluids
Extended Shaft Coupling VIL Pumps	S.A. Armstrong	ITT Fluids
Strainers	Sarco	Crane, McAvity, Morrison Brass, Braukmann
Suction Guides	S.A. Armstrong	ITT Fluids, Victualic
Automatic Air Vents	Sarco	Amtrol, Braukmann S.A. Armstrong Terice

BASE BID ITEM	ACCEPTABLE BASIS OF DESIGN	ALTERNATE
Backflow Preventors	Watts	Braukmann, Zurn-Wilkins
Make-Up Assemblies	Watts	S.A. Armstrong, Bell & Gossett, Mueller, Singer
Gauges, Thermometers	Trelice	Ashcroft, Weiss Weksler, Winters, Wika
Finned Tube Radiation and Convectors	Sigma	Dunham-Bush, Trane Engineered Air
Hot Water Unit Heaters and Cabinet Heaters	Sigma	Dunham-Bush, McQuay, Trane, Engineered Air
Steam Humidifiers	Engineered Air	Dri Steem
Hot Water Boilers	Boderus	
Prefabricated Chimneys	Van-Packer	Metal-Fab, Selkirk, ICC
Water Treatment	Aqurian	Alchem, Mogul, Culligan, Finnan
Fire Dampers	Controlled Air	Air Balance, Canadian Advanced Air, Ruskin
Louvre Insulated Blank-off Panels	Construction Specialties	
Air Terminal Devices (Diffusers, Registers, Grilles By-Pass Boxes)	E.H. Price	Nailor, Kruger, Carnes, Titus Tuttle & Bailey
Air Handling Unit	Engineered Air	McQuay, Trane, Haakon

BASE BID ITEM	ACCEPTABLE BASIS OF DESIGN	ALTERNATE
Heat Recovery Unit	Engineered Air	McQuay, Trane, Haakon
Fan Coil Units	Enviro-Tech	Trane, York
Misc. Fans	Cook	Carnes, Greenheck, ACME, Jenn-Air
Air Filters	Farr	Cambridge, Airguard, Vibron, A.A.F.
Filter Gauges	Dwyer	Airflow Developments (Canada) Ltd.
Dampers (Except low leakage)	Tamco	Johnson, Powers, Kerr Hunt, Honeywell, Barber-Coleman
Low Leakage Dampers	Tamco Series 9000	
Electrical Starters, Disconnects, MCC's, Alternator Panels	Square 'D'	Allen-Bradley, Klockner-Moeller
Noise and Vibration Control	Vibron	Korfund-Sampson, Vibro-Acoustics, Coolbreeze J.P. Environmental
Electric Pipe Tracing	Raychem	Serge-Baril
Trap Primers	PPP	
Plumbing Fixtures	American Standard	Crane, Kohler, Eljer
Floor Drains, Roof Drains, Cleanouts, Drainage Specialties	Zurn	Ancon J.R. Smith Mifab
Plumbing Trim	Chicago Faucets, Symmons	American Standard, Crane, Cambridge Brass

BASE BID ITEM	ACCEPTABLE BASIS OF DESIGN	ALTERNATE
Toilet Seats	Centoco	Beneke, Moldex, Olsonite
Domestic Water Heaters	Bradford-White	A.O. Smith, John Wood
Fire Extinguishers & Cabinets	National Fire Equipment	Wilson & Cousins
Washfountains	Bradley, Acorn	
S.S. Sinks	Aristaline	Kindred, Architectural Metal
Drinking Fountains	Haws	Sunroc
Emergency Eyewash	Haws	Bradley, Speakman
Mixing Valves	Symmons	Powers
Alarm Valves And Trim	Grinnell, Central	Reliable, Viking, Automatic, Victaulic
Siamese Connections	National Fire Equipment	Wilson & Cousins, Stelpro
Sprinkler Heads	Grinnell, Central	Reliable, Viking, Automatic, Victaulic
Equipment Cabinets	National Fire Equipment	Wilson & Cousins, Stelpro
Excess Pressure Pump	Albany	

1.9 ITEMIZED PRICES

These Itemized Prices will be used to identify the cost of components within the total Bid Sum required for the Owner's own internal auditing, exclusive of HST.

- .1 Supply and installation of Fire Alarm System complete with associated components, conduit and wiring as shown on drawing and described in specification.

_____ Dollars (\$_____)

- .2 Supply and installation of Dimming System complete with associated components, conduit and wiring as shown on drawing and described in specification.

_____ Dollars (\$_____)

- .3 Supply and installation of Security System complete with associated components, conduit and wiring as shown on drawing and described in specification.

_____ Dollars (\$_____)

1.10 SIGNING OF SUPPLEMENTARY FORM OF TENDER

PRINT COMPANY NAME: _____

PRINT NAME OF CONTACT PERSON
REGARDING THIS TENDER: _____

PRINT ADDRESS OF COMPANY: _____

PHONE NUMBER OF COMPANY: _____

PRINT NAME OF CONTACT PERSON
REGARDING THIS TENDER: _____

CONTACT PERSON'S EMAIL: _____

EMAIL ADDRESS SIGNING OFFICER: _____

SIGNATURE OF SIGNING OFFICER: _____

DATE: _____

PRINT NAME OF SIGNING OFFICER: _____

PRINT TITLE OF SIGNING OFFICER: _____

SIGNATURE OF WITNESS: _____

PRINT NAME OF WITNESS: _____

AFFIX CORPORATE SEAL (If no individual Witness):

END OF SECTION



2090 Shirley Drive Kitchener Ontario N2B 0A3
Phone: (519) 578.1000 Toll Free: (800) 265.8959 Fax: (519) 578.3262

Schedule of Finish Hardware

ARCHITECT/DESIGNER: 1721 ARCHITECTS
280 QUEENS AVE. 1Q
LONDON ON N6B 1X3
PHONE - 519-439-0611
FAX -

CONTRACTOR:

PHONE -
FAX -

PROJECT: MONSIGNOR DOYLE CSS
185 MYERS ROAD
CAMBRIDGE ON N1R 7H2
6290

PROJECT CONSULTANT: SIMON HANSON

PREPARED: February 22, 2024

REVISED: February 22, 2024

SUBMITTAL



Scan to check
out our website

DOOR INDEX

Mark	Heading #	Mark	Heading #	Mark	Heading #
100.1	100.1	104A	104A	113	113
100.2	100.2	104B	104B	114	114
101	101	105	105	115	115
101A	101A	106.1	106.1	116	116
101B	101B	106.2	106.2	117	117
101C	101C	106A	106A	118	118
101D	101D	106B	106B	118A	118A
101E	101E	107	107	119A	119A
101F	101F	108.1	108.1	119B	119B
102.1	102.1	108.2	108.2	120.1	120.1
102.2	102.2	108.3	108.3	120.2	120.2
102.3	102.3	108A.1	108A.1	120.3	120.3
102B.1	102B.1	108A.2	108A.2	120A	120A
102B.2	102B.2	109	109	121	121
102C	102C	110	110	122	122
102D	102D	110A.1	110A.1	123	123
103	103	110A.2	110A.2	124	124
103A	103A	110A.3	110A.3	125	125
103B	103B	111	111	126	126
103C	103C	112.1	112.1	127	127
104	104	112.2	112.2	128	128



KNELLS DOOR AND HARDWARE

MONSIGNOR DOYLE CSS

2090 SHIRLEY DRIVE

Control No.6290

KITCHENER

ON

N2B 0A3

6290

Tel: 519-578-1000

Fax: 519-578-3262

DOOR INDEX

Mark	Heading #	Mark	Heading #	Mark	Heading #
129	129	141	141	159A.3	159A.3
130	130	142	142	159C	159C
131	131	143	143	159D	159D
132	132	146	146	160	160
133	133	146A	146A	161.1	161.1
134A.1	134A.1	147	147	161A	161A
134A.2	134A.2	148	148	161B	161B
134B	134B	149	149	161C	161C
134C	134C	150	150	161D.1	161D.1
134D	134D	151	151	161D.2	161D.2
134E	134E	152	152	161E	161E
134 F	134F	153	153	162	162
134G	134G	154	154	162A	162A
135.1	135.1	155.1	155.1	162B	162B
135A	135A	155.2	155.2	163	163
136	136	156	156	164.1	164.1
137	137	157	157	164.2	164.2
138	138	158	158	164B	164B
139	139	159	159	165.1	165.1
140	140	159A.1	159A.1	165.2	165.2
140A	140A	159A.2	159A.2	166	166



KNELLS DOOR AND HARDWARE

MONSIGNOR DOYLE CSS

2090 SHIRLEY DRIVE

Control No.6290

KITCHENER

ON

N2B 0A3

6290

Tel: 519-578-1000

Fax: 519-578-3262

DOOR INDEX

Mark	Heading #	Mark	Heading #	Mark	Heading #
167.1	167.1	174	174	181.3	181.3
167.2	167.2	175.1	175.1	182B.1	182B.1
168.1	168.1	175.2	175.2	182B.2	182B.2
168.2	168.2	176	176	182B.3	182B.3
169.1	169.1	177.1	177.1	182B.4	182B.4
169.2	169.2	177.2	177.2	182.1	182.1
169B	169B	178.1	178.1	182.2	182.2
170.1	170.1	178.2	178.2	182.3	182.3
170.2	170.2	178A	178A	182A.1	182A.1
171	171	178B	178B	182A.2	182A.2
171A	171A	178C	178C	182C	182C
172	172	178D	178D	182D	182D
173	173	178E	178E	182E.1	182E.1
173A	173A	179	179	182E.2	182E.2
173B	173B	179A	179A	182E.3	182E.3
173C	173C	180.1	180.1	182E.4	182E.4
173D	173D	180.2	180.2	182E.5	182E.5
173E	173E	180.3	180.3	182E.6	182E.6
173 F	173F	180A	180A	182 F	182F
173G	173G	181.1	181.1	182H	182H
173H	173H	181.2	181.2	183	183



KNELLS DOOR AND HARDWARE

MONSIGNOR DOYLE CSS

2090 SHIRLEY DRIVE

Control No.6290

KITCHENER

ON

N2B 0A3

6290

Tel: 519-578-1000

Fax: 519-578-3262

DOOR INDEX

Mark	Heading #	Mark	Heading #	Mark	Heading #
183A	183A	194.2	194.2	205	205
184	184	195	195	206	206
185	185	196	196	207	207
186.1	186.1	196B	196B	208	208
186.2	186.2	196C	196C	209	209
186A	186A	196D	196D	210	210
186B	186B	196E.1	196E.1	211	211
188.1	188.1	196E.2	196E.2	212	212
188.2	188.2	196F	196F		
189.1	189.1	196G	196G		
189.2	189.2	196H	196H		
190.1	190.1	196J	196J		
190.2	190.2	196K	196K		
191	191	196L.1	196L.1		
191A	191A	196M	196M		
191B	191B	197.1	197.1		
192.1	192.1	197.2	197.2		
192.2	192.2	197A	197A		
193	193	197B	197B		
193A	193A	201	201		
194.1	194.1	204	204		



KNELLS DOOR AND HARDWARE

2090 SHIRLEY DRIVE

KITCHENER

Tel: 519-578-1000

ON

N2B 0A3

Fax: 519-578-3262


MONSIGNOR DOYLE CSS

Control No.6290

6290

Hardware Finishes

Finish	Description
26D	SATIN CHROMIUM PLATED
32D	SATIN STAINLESS STEEL, 300 SERIES
622	BLACK - DULL
626	SATIN CHROMIUM
630	SATIN STAINLESS STEEL
689	POWDER COAT, ALUMINUM
ALUMINUM	ALUMINUM
C.A.	CLEAR ANODIZED
C26D	SATIN CHROMIUM
C32D	STAINLESS STEEL, SATIN
CL	CLEAR
CLEAR	CLEAR ANODIZED
PC	PRIME COAT
US26D	SATIN CHROMIUM PLATED
US26D/US32D	STAINLESS STEEL - SATIN
US32D	SATIN STAINLESS STEEL

	KNELLS DOOR AND HARDWARE	MONSIGNOR DOYLE CSS
	2090 SHIRLEY DRIVE	Control No.6290
	KITCHENER ON N2B 0A3	6290
	Tel: 519-578-1000 Fax: 519-578-3262	

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 100.1

1 SGL DOOR 100.1 EXTERIOR FROM VEST. 100

° LHR

1065 x 2155 x 44 ALD Door/ ALF Frame

NON-RTD Door/NON-RTD Frame

1	CONTINUOUS HINGE	SL11 CL HD X 2159MM X SDTF	CL	SEL
1	RIM EXIT DEVICE EXIT ONLY OR DUMMY TRIM	16-8810J 1065MMW X NO TRIM X 649 (DEVCYL-NONE)	US32D	SAR
1	CYLINDER	10J0200-26-DQM-Z20	26	MED
1	EXTERIOR CYLINDER	10K0403-26-7GS (KEYMARK CYLINDER FOR SARGENT EXITS)	626	G&A
1	ELECTRIC STRIKE	9400-12/24D-630	630	ESH
1	PULL	GSH 1180-2 X THROUGH BOLT MOUNTING	C32D	GAL
1	OVERHEAD STOP/HOLDER, CONCEALED	105S	US32D	GLY
1	AUTO OPERATOR	MICOM KIT 18139 WIRED (SW800 ADO & 2 BUTTONS-INSTALLED)		G&A
1	DOOR SWEEP	W-38S X 1065MMW	C.A.	KNC
1	THRESHOLD	CT-75 X 1065MM	ALUMINUM	KNC
2	ACTUATOR 36"	CM-7536/4		CAM
2	BACKBOX	CM-75SB	GREY	CAM

INTEGRAL WEATHERSTRIP BY ALUMINUM SUPPLIER.
KEYMARK EXTERIOR CYLINDER TO BE SUPPLIED AT JOB COMPLETION.
110VAC TO HEADER, ALL CONDUIT AND PULL STRINGS BY OTHERS.
CARD READER BY OWLTECH.

Heading # 100.2

1 PR DOORS 100.2 EXTERIOR FROM VEST. 100

° LHR,RHR

915/915 x 2155 x 44 ALD Door/ ALF Frame

NON-RTD Door/NON-RTD Frame

2	CONTINUOUS HINGE	SL11 CL HD X 2159MM X SDTF	CL	SEL
2	RIM EXIT DEVICE EXIT ONLY OR DUMMY TRIM	16-8810F 915MMW X NO TRIM X 649 (DEVCYL-NONE)	US32D	SAR
2	CYLINDER	10J0200-26-DQM-Z20	26	MED
2	PULL	GSH 1180-2 X THROUGH BOLT MOUNTING	C32D	GAL
2	OVERHEAD STOP	104S	US32D	GLY
2	CLOSER	4040XP.RWPA.689	689	LCN
2	DOOR SWEEP	W-38S X 915MMW	C.A.	KNC
2	THRESHOLD	CT-75 X 915MM	ALUMINUM	KNC
2	MISCELLANEOUS	4020-18G.689	689	LCN

INTEGRAL WEATHERSTRIP BY ALUMINUM SUPPLIER.

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 101

1 SGL DOOR 101 CORRIDOR FROM MAIN OFFICE 101

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C32D	GAL

Heading # 101A

1 SGL DOOR 101A MAIN OFFICE 101 TO VICE PRINCIPAL 101A

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	WALL STOP	GSH 240	C32D	GAL

Heading # 101B

1 SGL DOOR 101B MAIN OFFICE 101 TO PRINCIPAL 101B

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	WALL STOP	GSH 240	C32D	GAL

Heading # 101C

1 SGL DOOR 101C MAIN OFFICE 101 TO OFFICE 101C

° LH

x x WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	WALL STOP	GSH 240	C32D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 101D

1 SGL DOOR 101D MAIN OFFICE 101 TO MEETING ROOM 101D			°	LH
900 x 2150 x 44 WD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	WALL STOP	GSH 240	C32D	GAL

Heading # 101E

1 SGL DOOR 101E MAIN OFFICE 101 TO SSDA V.P. OFFICE 101E			°	LH
x x WD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	WALL STOP	GSH 240	C32D	GAL

Heading # 101F

1 SGL DOOR 101F WORK ROOM 101G TO STORAGE 101F			°	LH
ex. x ex. x XHMD Door/ XHMF Frame			45 MIN Door/45 MIN Frame	
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 102.1

1 SGL DOOR 102.1 CORRIDOR FROM ATTENDANCE/ HEALTH UNIT 102			°	LHR
900 x 2150 x 44 WD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	CLOSER	4040XP.RWPA.689.SRT	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 102.2

1 SGL DOOR 102.2 MAIN OFFICE 101 TO ATTENDANCE/ HEALTH UNIT 102

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C32D	GAL

Heading # 102.3

1 SGL DOOR 102.3 MAIN OFFICE 101 TO ATTENDANCE/ HEALTH UNIT 102

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C32D	GAL

Heading # 102B.1

1 SGL DOOR 102B.1 OFFICE 102B FROM ATTENDANCE/ HEALTH UNIT 102

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 102B.2

1 SGL DOOR 102B.2 MAIN OFFICE 101 TO OFFICE 102B

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C32D	GAL

Heading # 102C

1 SGL DOOR 102C OFFICE 102B TO NURSE 102C

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	PRIVACY SET	175L X E7	26D	MRK
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C32D	GAL

Heading # 102D

1 SGL DOOR 102D OFFICE 102B TO H. W/R 102D

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	PASSAGE SET	175N X E7	26D	MRK
1	INDICATOR DEADBOLT	D271 X 30-253 X 10-094	626	FAL
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	DOOR SWEEP	W-13S X 36	CLEAR	KNC

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 103

1 PR DOORS 103 CORRIDOR FROM SCHOOL INFO. CENTRE 103

° LHR,RHR

900/900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

6	HINGE, 4 1/2, HVY WT	MPB99 114MM X 114MM NRP	32D	MCK
1	MULLION	L980 X 120	PC	SAR
1	RIM EXIT DEVICE	16-8810F 900MMW X NO TRIM X 649 (DEVCYL-NONE)	US32D	SAR
1	RIM EXIT DEVICE KEY RETRACTS LATCH BOLT	16-8804F 900MMW X NO TRIM X 649 X KD (DEVCYL-W/ X 0-BITTED) X W/CYLINDER	US32D	SAR
5	CYLINDER	10J0200-26-DQM-Z20	26	MED
2	PULL	GSH 1180-2 X #2	C32D	GAL
1	OVERHEAD STOP	904S	US32D	GLY
2	CLOSER	4040XP.RWPA.689	689	LCN
2	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C32D	GAL
2	DROP PLATE	4040XP-18G.689	689	LCN

Heading # 103A

1 SGL DOOR 103A SCHOOL INFO. CENTRE 103 TO OFFICE 103A

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	WALL STOP	GSH 240	C32D	GAL

Heading # 103B

1 SGL DOOR 103B SCHOOL INFO. CENTRE 103 TO A.V. EQUIPMENT 103B

° RH

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 103C

1 SGL DOOR 103C SCHOOL INFO. CENTRE 103 TO STORAGE 103C

° LH

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 104

1 SGL DOOR 104 CORRIDOR FROM STUDENT ACTIVITIES 104

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 104A

1 SGL DOOR 104A STUDENT ACTIVITIES 104 TO OFFICE 104A

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	WALL STOP	GSH 240	C32D	GAL

Heading # 104B

1 SGL DOOR 104B STUDENT ACTIVITIES 104 TO STORAGE 104B

° RH

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	CLASSROOM LOCK	175S X E7 X G3	26D	MRK
1	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 105

1 SGL DOOR 105 CORRIDOR TO H. W/R 105

° LH

915 x 2135 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	INDICATOR DEADBOLT	D271 X 30-253 X 10-094	626	FAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 106.1

1 SGL DOOR 106.1 CORRIDOR FROM SCIENCE PHYSICS 106

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 106.2

1 SGL DOOR 106.2 CORRIDOR FROM SCIENCE PHYSICS 106

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 106A

1 SGL DOOR 106A PREP. AREA 106B FROM CHEMICAL STORAGE 106A

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN
1	DROP PLATE	4040XP-18G.689	689	LCN

Heading # 106B

1 SGL DOOR 106B SCIENCE PHYSICS 106 TO PREP. AREA 106B

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	CLOSER	4040XP.RWPA.689	689	LCN
1	WALL STOP	GSH 240	C32D	GAL

Heading # 107

1 SGL DOOR 107 CORRIDOR FROM CUST. RM. 107

° RHR

900 x 2150 x 44 HMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	DROP PLATE	4040XP-18G.689	689	LCN

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 108.1

1 SGL DOOR 108.1 CORRIDOR FROM SCIENCE PREP. 108

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL
1	DROP PLATE	4040XP-18G.689	689	LCN

Heading # 108.2

1 SGL DOOR 108.2 SCIENCE PREP. 108 FROM SCIENCE CHEMISTRY 109

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INSTITUTION LOCK	175DW X E7 X G3	26D	MRK
1	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY

Heading # 108.3

1 SGL DOOR 108.3 SCIENCE PREP. 108 FROM SCIENCE PHYSICS 106

° RHR

915 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INSTITUTION LOCK	175DW X E7 X G3	26D	MRK
1	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 108A.1

1 SGL DOOR 108A.1 SCIENCE PREP. 108 FROM STAFF WORK RM. 108A

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	WALL STOP	GSH 240	C32D	GAL

Heading # 108A.2

1 SGL DOOR 108A.2 STAFF WORK RM. 108A TO PREP. AREA 106B

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 109

1 SGL DOOR 109 CORRIDOR FROM SCIENCE CHEMISTRY 109

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	DROP PLATE	4040XP-18G.689	689	LCN

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 110

1 SGL DOOR 110 CORRIDOR FROM SCIENCE GENERAL 110

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 110A.1

1 SGL DOOR 110A.1 SCIENCE STORAGE 111 FROM SCIENCE PREP. 110A

° LHR

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 110A.2

1 SGL DOOR 110A.2 SCIENCE PREP. 110A TO SCIENCE BIOLOGY 112

° RH

ex. x ex. x WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	INSTITUTION LOCK	175DW X E7 X G3	26D	MRK
1	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 110A.3

1 SGL DOOR 110A.3 SCIENCE GENERAL 110 FROM SCIENCE PREP. 110A

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INSTITUTION LOCK	175DW X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 111

1 SGL DOOR 111 CORRIDOR FROM SCIENCE STORAGE 111

° LHR

900 x 2150 x 44 HMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	DROP PLATE	4040XP-18G.689	689	LCN

Heading # 112.1

1 SGL DOOR 112.1 CORRIDOR FROM SCIENCE BIOLOGY 112

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 112.2

1 SGL DOOR 112.2 CORRIDOR FROM SCIENCE BIOLOGY 112

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 113

1 SGL DOOR 113 CORRIDOR TO MEN W/R 113

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	CYLINDER	20J009S4-26-DQM	26D	MED
1	CLASSROOM DEADBOLT	B663.B.626.12-631	626	SAN
1	PUSH PLATE	GSH 81A X 2-SIDED TAPE X 127MM X 508MM	C32D	GAL
1	PULL	4609-1 X THROUGH BOLT MOUNTING	C32D	GAL
1	PULL	GSH 981 X #2	C32D	GAL
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 114

1 SGL DOOR 114 CORRIDOR TO CUST. RM. 114

° LH

900 x 2150 x 44 HMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 115

1 SGL DOOR 115 CORRIDOR TO WOMEN W/R 115

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	CYLINDER	20J009S4-26-DQM	26D	MED
1	CLASSROOM DEADBOLT	B663.B.626.12-631	626	SAN
1	PUSH PLATE	GSH 81A X 2-SIDED TAPE X 127MM X 508MM	C32D	GAL
1	PULL	4609-1 X THROUGH BOLT MOUNTING	C32D	GAL
1	PULL	GSH 981 X #2	C32D	GAL
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 116

1 SGL DOOR 116 CORRIDOR TO STAFF W/R 116			°	RH
900 x 2150 x 44 WD Door/ XHMF Frame				NON-RTD Door/NON-RTD Frame
3 HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM		26D	MCK
1 STOREROOM LOCK	175F X E7 X G3		26D	MRK
1 CYLINDER	20J200V1-26-DQM (AB,F)		626	G&A
1 INDICATOR DEADBOLT	D271 X 30-253 X 10-094		626	FAL
1 WALL STOP	GSH 240		C26D	GAL

Heading # 117

1 SGL DOOR 117 CORRIDOR TO STAFF W/R 117			°	LH
900 x 2150 x 44 WD Door/ XHMF Frame				NON-RTD Door/NON-RTD Frame
3 HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM		26D	MCK
1 STOREROOM LOCK	175F X E7 X G3		26D	MRK
1 CYLINDER	20J200V1-26-DQM (AB,F)		626	G&A
1 INDICATOR DEADBOLT	D271 X 30-253 X 10-094		626	FAL
1 WALL STOP	GSH 240		C26D	GAL

Heading # 118

1 SGL DOOR 118 CORRIDOR FROM LEARNING RESOURCES I 118			°	RHR
900 x 2150 x 44 WD Door/ XHMF Frame				NON-RTD Door/NON-RTD Frame
3 HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM		26D	MCK
1 INTRUDER LOCKSET	195DB X G3		26D	MRK
2 CYLINDER	20J200V0-26-DQM (DB,S)		626	G&A
1 OVERHEAD STOP	904S		US32D	GLY
1 KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM		C32D	GAL

Heading # 118A

1 SGL DOOR 118A LEARNING RESOURCES I 118 FROM W/R 118A			°	RHR
900 x 2150 x 44 WD Door/ XHMF Frame				NON-RTD Door/NON-RTD Frame
3 HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM		26D	MCK
1 PRIVACY SET	175L X E7		26D	MRK
1 OVERHEAD STOP	904S		US32D	GLY

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 119A

1 SGL DOOR 119A CORRIDOR TO SEMINAR I 119A

° RH

915 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 875MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 119B

1 SGL DOOR 119B CORRIDOR FROM SEMINAR II 119B

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 120.1

1 SGL DOOR 120.1 CORRIDOR FROM LEARNING RESOURCES II 120

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 120.2

1 SGL DOOR 120.2 LEARNING RESOURCES I 118 TO LEARNING RESOURCES II 120

° RH

1065 x 2135 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INSTITUTION LOCK	175DW X E7 X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 120.3

1 SGL DOOR 120.3 LEARNING RESOURCES II 120 FROM CLASSROOM 122

° LHR

1065 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INSTITUTION LOCK	175DW X E7 X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 120A

1 SGL DOOR 120A LEARNING RESOURCES II 120 TO OFFICE 120A

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 121

1 SGL DOOR 121 CORRIDOR FROM COMPUTER C/R 121

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 122

1 SGL DOOR 122 CORRIDOR FROM CLASSROOM 122

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 123

1 SGL DOOR 123 CORRIDOR FROM CLASSROOM 123

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 124

1 SGL DOOR 124 CORRIDOR TO MEN W/R 124

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	CYLINDER	20J009S4-26-DQM	26D	MED
1	CLASSROOM DEADBOLT	B663.B.626.12-631	626	SAN
1	PUSH PLATE	GSH 81A X 2-SIDED TAPE X 127MM X 508MM	C32D	GAL
1	PULL	4609-1 X THROUGH BOLT MOUNTING	C32D	GAL
1	PULL	GSH 981 X #2	C32D	GAL
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 125

1 SGL DOOR 125 CORRIDOR TO WOMEN W/R 125

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	CYLINDER	20J009S4-26-DQM	26D	MED
1	CLASSROOM DEADBOLT	B663.B.626.12-631	626	SAN
1	PUSH PLATE	GSH 81A X 2-SIDED TAPE X 127MM X 508MM	C32D	GAL
1	PULL	4609-1 X THROUGH BOLT MOUNTING	C32D	GAL
1	PULL	GSH 981 X #2	C32D	GAL
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 126

1 SGL DOOR 126 CORRIDOR TO CUST. 126

° LH

ex. x ex. x XHMD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 127

1 SGL DOOR 127 CORRIDOR TO H. W/R 127

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	INDICATOR DEADBOLT	D271 X 30-253 X 10-094	626	FAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 128

1 SGL DOOR 128 CORRIDOR TO UNIV. W/R 128

° LH

965 x 2150 x 44 WD Door/ HMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	ELECTRIC STRIKE	5000C-12/24D-630	630	ESH
1	AUTO OPERATOR	MICOM KIT 18137 PREM UNIV WASH (SW800 ADO, AURA & EMERG CALL-INSTALLED)		G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

110VAC TO HEADER, ALL CONDUIT AND PULL STRINGS BY OTHERS.

Heading # 129

1 SGL DOOR 129 CORRIDOR TO STAFF W/R WOMEN 129

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	CLOSER	4040XP.RWPA.689	689	LCN
1	WALL STOP	GSH 240	C26D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 130

1 SGL DOOR 130 CORRIDOR TO CLASSROOM 130

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 131

1 SGL DOOR 131 CORRIDOR TO CLASSROOM 131

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 132

1 SGL DOOR 132 CORRIDOR TO CLASSROOM 132

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 133

1 SGL DOOR 133 VEST. D TO WATER SERVICE 133

° LH

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 134A.1

1 PR DOORS 134A.1 CORRIDOR FROM GYM A 134A

° LHR,RHR

900/900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

6	HINGE, 4 1/2, HVY WT	MPB99 114MM X 114MM NRP	32D	MCK
1	MULLION	L980 X 120	PC	SAR
2	RIM EXIT DEVICE	16-8810F 900MMW X NO TRIM X 649 (DEVCYL-NONE)	US32D	SAR
5	CYLINDER	10J0200-26-DQM-Z20	26	MED
2	OVERHEAD STOP	904S	US32D	GLY
2	CLOSER	4040XP.RWPA.689	689	LCN
2	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
2	DROP PLATE	4040XP-18G.689	689	LCN

Heading # 134A.2

1 PR DOORS 134A.2 CORRIDOR FROM GYM A 134A

° LHR,RHR

900/900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

6	HINGE, 4 1/2, HVY WT	MPB99 114MM X 114MM NRP	32D	MCK
1	MULLION	L980 X 120	PC	SAR
2	RIM EXIT DEVICE	16-8810F 900MMW X NO TRIM X 649 (DEVCYL-NONE)	US32D	SAR
5	CYLINDER	10J0200-26-DQM-Z20	26	MED
2	PULL	4609-1 X THROUGH BOLT MOUNTING	C32D	GAL
2	OVERHEAD STOP	904S	US32D	GLY
2	CLOSER	4040XP.RWPA.689	689	LCN
2	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
2	DROP PLATE	4040XP-18G.689	689	LCN

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 134B

1 PR DOORS 134B CORRIDOR FROM GYM B 134B

° LHR,RHR

900/900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

6	HINGE, 4 1/2, HVY WT	MPB99 114MM X 114MM NRP	32D	MCK
1	MULLION	L980 X 120	PC	SAR
2	RIM EXIT DEVICE	16-8810F 900MMW X NO TRIM X 649 (DEVCYL-NONE)	US32D	SAR
5	CYLINDER	10J0200-26-DQM-Z20	26	MED
2	PULL	4609-1 X THROUGH BOLT MOUNTING	C32D	GAL
2	OVERHEAD STOP	904S	US32D	GLY
2	CLOSER	4040XP.RWPA.689	689	LCN
2	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
2	DROP PLATE	4040XP-18G.689	689	LCN

Heading # 134C

1 PR DOORS 134C CORRIDOR FROM GYM C 134C

° LHR,RHR

900/900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

6	HINGE, 4 1/2, HVY WT	MPB99 114MM X 114MM NRP	32D	MCK
1	MULLION	L980 X 120	PC	SAR
2	RIM EXIT DEVICE	16-8810F 900MMW X NO TRIM X 649 (DEVCYL-NONE)	US32D	SAR
5	CYLINDER	10J0200-26-DQM-Z20	26	MED
2	PULL	4609-1 X THROUGH BOLT MOUNTING	C32D	GAL
2	OVERHEAD STOP	904S	US32D	GLY
2	CLOSER	4040XP.RWPA.689	689	LCN
2	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
2	DROP PLATE	4040XP-18G.689	689	LCN

Heading # 134D

1 PR DOORS 134D GYM A 134A TO GYM A - STORAGE 134D

° LH,RH

0/0 x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	CYLINDER	10J0200-26-DQM (MORTISE CYLINDER)	626	MED
---	----------	-----------------------------------	-----	-----

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

CYLINDER TYPE TO BE CONFIRMED

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 134E

1 PR DOORS 134E GYM B 134B FROM 134E	°	LHR,RHR	
0/0 x ex. x XHMD Door/ XHMF Frame		NON-RTD Door/NON-RTD Frame	
5 CYLINDER 10J0200-26-DQM-Z20		26	MED
NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.			
CYLINDER TYPE TO BE CONFIRMED			

Heading # 134F

1 PR DOORS 134 F 134E TO GYM B - STORAGE 134F	°	LH,RH	
0/0 x ex. x HMD Door/ XHMF Frame		NON-RTD Door/NON-RTD Frame	
1 STOREROOM LOCK 175F X E7 X G3		26D	MRK
1 CYLINDER 20J200V1-26-DQM (AB,F)		626	G&A
NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.			

Heading # 134G

1 PR DOORS 134G GYM C 134C TO GYM C - STORAGE 134G	°	LH,RH	
0/0 x ex. x XHMD Door/ XHMF Frame		NON-RTD Door/NON-RTD Frame	
1 STOREROOM LOCK 175F X E7 X G3		26D	MRK
1 CYLINDER 20J200V1-26-DQM (AB,F)		626	G&A
NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.			

Heading # 135.1

1 SGL DOOR 135.1 CORRIDOR TO PHYS. ED 135	°	RH	
ex. x ex. x XHMD Door/ XHMF Frame		NON-RTD Door/NON-RTD Frame	
1 STOREROOM LOCK 175F X E7 X G3		26D	MRK
1 CYLINDER 20J200V1-26-DQM (AB,F)		626	G&A
NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.			

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 135A

1 SGL DOOR 135A CORRIDOR FROM STAIR 135A

° LHR

1100 x 2150 x HMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	CLOSER	4040XP.RWPA.689	689	LCN
1	WALL STOP	GSH 240	C32D	GAL

Heading # 136

1 SGL DOOR 136 CORRIDOR TO CHANGE RM. WOMEN 136

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	CYLINDER	20J009S4-26-DQM	26D	MED
1	CLASSROOM DEADBOLT	B663.B.626.12-631	626	SAN
1	PUSH PLATE	GSH 81A X 2-SIDED TAPE X 127MM X 508MM	C32D	GAL
1	PULL	4609-1 X THROUGH BOLT MOUNTING	C32D	GAL
1	PULL	GSH 981 X #2	C32D	GAL
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 137

1 SGL DOOR 137 CORRIDOR TO CHANGE RM. WOMEN 137

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	CYLINDER	20J009S4-26-DQM	26D	MED
1	CLASSROOM DEADBOLT	B663.B.626.12-631	626	SAN
1	PUSH PLATE	GSH 81A X 2-SIDED TAPE X 127MM X 508MM	C32D	GAL
1	PULL	4609-1 X THROUGH BOLT MOUNTING	C32D	GAL
1	PULL	GSH 981 X #2	C32D	GAL
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 138

1 SGL DOOR 138 CORRIDOR TO CHANGE RM. MEN 138

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	CYLINDER	20J009S4-26-DQM	26D	MED
1	CLASSROOM DEADBOLT	B663.B.626.12-631	626	SAN
1	PUSH PLATE	GSH 81A X 2-SIDED TAPE X 127MM X 508MM	C32D	GAL
1	PULL	4609-1 X THROUGH BOLT MOUNTING	C32D	GAL
1	PULL	GSH 981 X #2	C32D	GAL
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 139

1 SGL DOOR 139 CORRIDOR TO CHANGE RM. MEN 139

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	CYLINDER	20J009S4-26-DQM	26D	MED
1	CLASSROOM DEADBOLT	B663.B.626.12-631	626	SAN
1	PUSH PLATE	GSH 81A X 2-SIDED TAPE X 127MM X 508MM	C32D	GAL
1	PULL	4609-1 X THROUGH BOLT MOUNTING	C32D	GAL
1	PULL	GSH 981 X #2	C32D	GAL
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 140

1 SGL DOOR 140 CORRIDOR TO PHYS. ED 140

° LH

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 140A

1 SGL DOOR 140A CORRIDOR FROM STAIR 140A			°	RHR
ex. x ex. x XHMD Door/ XHMF Frame				NON-RTD Door/NON-RTD Frame
1 STOREROOM LOCK	175F X E7 X G3		26D	MRK
1 CYLINDER	20J200V1-26-DQM (AB,F)		626	G&A
NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.				

Heading # 141

1 SGL DOOR 141 CORRIDOR TO CHANGE RM 141			°	LH
900 x 2150 x 44 WD Door/ XHMF Frame				NON-RTD Door/NON-RTD Frame
3 HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM		26D	MCK
1 CYLINDER	20J009S4-26-DQM		26D	MED
1 CLASSROOM DEADBOLT	B663.B.626.12-631		626	SAN
1 PUSH PLATE	GSH 81A X 2-SIDED TAPE X 127MM X 508MM		C32D	GAL
1 PULL	4609-1 X THROUGH BOLT MOUNTING		C32D	GAL
1 PULL	GSH 981 X #2		C32D	GAL
1 CLOSER	4040XP.RWPA.689		689	LCN
1 KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM		C32D	GAL
1 WALL STOP	GSH 240		C26D	GAL

Heading # 142

1 SGL DOOR 142 CORRIDOR TO FITNESS CENTRE			°	RH
900 x 2150 x 44 WD Door/ XHMF Frame				NON-RTD Door/NON-RTD Frame
3 HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM		26D	MCK
1 CLASSROOM LOCK	175S X E7 X G3		26D	MRK
2 CYLINDER	20J200V0-26-DQM (DB,S)		626	G&A
1 KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM		C32D	GAL
1 WALL STOP	GSH 240		C26D	GAL

Heading # 143

1 SGL DOOR 143 CORRIDOR FROM MACH. 143			°	RHR
ex x ex x XHMD Door/ XHMF Frame				NON-RTD Door/NON-RTD Frame
1 STOREROOM LOCK	175F X E7 X G3		26D	MRK
1 CYLINDER	20J200V1-26-DQM (AB,F)		626	G&A
NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.				

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 146

1 SGL DOOR 146 CORRIDOR TO W/R 146

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	INDICATOR DEADBOLT	D271 X 30-253 X 10-094	626	FAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 146A

1 SGL DOOR 146A W/R 146 TO ELEC. RM 146A

° LH

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 147

1 SGL DOOR 147 CORRIDOR TO CLASSROOM 147

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 148

1 SGL DOOR 148 CORRIDOR TO CLASSROOM 148

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 149

1 SGL DOOR 149 CORRIDOR TO CLASSROOM 149

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 150

1 SGL DOOR 150 CORRIDOR TO CLASSROOM 150

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 151

1 SGL DOOR 151 CORRIDOR TO CLASSROOM 151

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 152

1 SGL DOOR 152 CORRIDOR TO STORAGE 152

° RH

900 x 2150 x 44 XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	CLOSER	4040XP.RWPA.689	689	LCN
1	WALL STOP	GSH 240	C32D	GAL

Heading # 153

1 SGL DOOR 153 CORRIDOR TO CLASSROOM 153

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 154

1 SGL DOOR 154 CORRIDOR TO CLASSROOM 154

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 155.1

1 SGL DOOR 155.1 CORRIDOR TO FITNESS CENTRE 155			°	LH
900 x 2150 x 44 HMD Door/ XHMF Frame				NON-RTD Door/NON-RTD Frame
3 HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM		26D	MCK
1 INTRUDER LOCKSET	195DB X G3		26D	MRK
2 CYLINDER	20J200V0-26-DQM (DB,S)		626	G&A
1 KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM		C32D	GAL
1 WALL STOP	GSH 240		C26D	GAL

Heading # 155.2

1 SGL DOOR 155.2 CORRIDOR TO FITNESS CENTRE 155			°	LH
900 x 2150 x 44 HMD Door/ XHMF Frame				NON-RTD Door/NON-RTD Frame
3 HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM		26D	MCK
1 INTRUDER LOCKSET	195DB X G3		26D	MRK
2 CYLINDER	20J200V0-26-DQM (DB,S)		626	G&A
1 KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM		C32D	GAL
1 WALL STOP	GSH 240		C26D	GAL

Heading # 156

1 SGL DOOR 156 CORRIDOR TO CLASSROOM 156			°	RH
900 x 2150 x 44 WD Door/ XHMF Frame				NON-RTD Door/NON-RTD Frame
3 HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM		26D	MCK
1 INTRUDER LOCKSET	195DB X G3		26D	MRK
2 CYLINDER	20J200V0-26-DQM (DB,S)		626	G&A
1 KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM		C32D	GAL
1 WALL STOP	GSH 240		C26D	GAL

Heading # 157

1 SGL DOOR 157 CORRIDOR TO STORAGE 157			°	LH
ex x ex x XHMD Door/ XHMF Frame				NON-RTD Door/NON-RTD Frame
1 STOREROOM LOCK	175F X E7 X G3		26D	MRK
1 CYLINDER	20J200V1-26-DQM (AB,F)		626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 158

1 SGL DOOR 158 CORRIDOR TO CLASSROOM 158

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 159

1 PR DOORS 159 CORRIDOR FROM CONSTRUCTION TECH. 159

° LHR,RHR

900/900 x 2150 x 44 HMD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

6	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
2	FLUSH BOLT	282D	US26D	HAG
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
2	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN

Heading # 159A.1

1 SGL DOOR 159A.1 CONSTRUCTION TECH. 159 TO 159A

° RH

1100 x 2150 x 44 HMD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	CLOSER	4040XP.RWPA.689	689	LCN
1	WALL STOP	GSH 240	C32D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 159A.2

1 SGL DOOR 159A.2 159A FROM COMPUTER TECHNOLOGY 164

° LHR

1100 x 2150 x 44 HMD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN

Heading # 159A.3

1 SGL DOOR 159A.3 159A FROM AUTOMOTIVE 171

° RHR

1100 x 2150 x 44 HMD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	CLOSER	4040XP.RWPA.689	689	LCN
1	WALL STOP	GSH 240	C32D	GAL

Heading # 159C

1 SGL DOOR 159C CONSTRUCTION TECH. 159 FROM STORAGE 159C

° LHR

1100 x 2150 x 44 HMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN
1	DROP PLATE	4040XP-18G.689	689	LCN

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 159D

1 SGL DOOR 159D STORAGE 159C FROM COMP. RM 159D

° RHR

900 x 2150 x 44 HMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	CLOSER	4040XP.RWPA.689	689	LCN
1	WALL STOP	GSH 240	C32D	GAL

Heading # 160

1 PR DOORS 160 CORRIDOR FROM COMMUNICATION TECH. 160

° LHR,RHR

900/900 x 2150 x 44 HMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

6	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
2	FLUSH BOLT	282D	US26D	HAG
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
2	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN

Heading # 161.1

1 SGL DOOR 161.1 CORRIDOR FROM COMMUNICATION TECH. 161

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 161A

1 SGL DOOR 161A COMMUNICATION TECH. 161 TO STORAGE 161A

° LH

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 161B

1 PR DOORS 161B COMMUNICATION TECH. 161 FROM STUDIO 161B

° LHR,RHR

900/900 x 2135 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

6	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
2	FLUSH BOLT	282D	US26D	HAG
1	PASSAGE SET	175N X E7	26D	MRK
2	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN

Heading # 161C

1 PR DOORS 161C STUDIO 161B FROM 161C

° LHR,RHR

900/900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

6	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
2	FLUSH BOLT	282D	US26D	HAG
1	PASSAGE SET	175N X E7	26D	MRK
2	OVERHEAD STOP	904S	US32D	GLY

Heading # 161D.1

1 SGL DOOR 161D.1 COMMUNICATION TECH. 161 FROM CONTROL RM. 161D

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	CLASSROOM LOCK	175S X E7 X G3	26D	MRK
1	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 161D.2

1 SGL DOOR 161D.2 STUDIO 161B FROM CONTROL RM. 161D

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	CLASSROOM LOCK	175S X E7 X G3	26D	MRK
1	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY

Heading # 161E

1 SGL DOOR 161E COMMUNICATION TECH. 161 FROM EDITING 161E

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C32D	GAL

Heading # 162

1 SGL DOOR 162 CORRIDOR TO PHYS. INSTR. 162

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 162A

1 SGL DOOR 162A PHYS. INSTR. 162 TO WOMEN W/R 162A

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	CYLINDER	20J009S4-26-DQM	26D	MED
1	CLASSROOM DEADBOLT	B663.B.626.12-631	626	SAN
1	PUSH PLATE	GSH 81A X 2-SIDED TAPE X 127MM X 508MM	C32D	GAL
1	PULL	4609-1 X THROUGH BOLT MOUNTING	C32D	GAL
1	PULL	GSH 981 X #2	C32D	GAL
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 162B

1 SGL DOOR 162B PHYS. INSTR. 162 TO MEN W/R 162B

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	CYLINDER	20J009S4-26-DQM	26D	MED
1	CLASSROOM DEADBOLT	B663.B.626.12-631	626	SAN
1	PUSH PLATE	GSH 81A X 2-SIDED TAPE X 127MM X 508MM	C32D	GAL
1	PULL	4609-1 X THROUGH BOLT MOUNTING	C32D	GAL
1	PULL	GSH 981 X #2	C32D	GAL
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 163

1 SGL DOOR 163 CORRIDOR TO CUST. 163

° RH

900 x 2150 x 44 HMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	CLOSER	4040XP.RWPA.689	689	LCN
1	WALL STOP	GSH 240	C32D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 164.1

1 PR DOORS 164.1 CORRIDOR FROM COMPUTER TECHNOLOGY 164

° LHR,RHR

900/900 x 2150 x 44 HMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

6	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
2	FLUSH BOLT	282D	US26D	HAG
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
2	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN

Heading # 164.2

1 SGL DOOR 164.2 COMPUTER TECHNOLOGY 164 TO COMMUNICATION TECH. 161

° LH

1100 x 2150 x 44 HMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INSTITUTION LOCK	175DW X E7 X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C32D	GAL

Heading # 164B

1 SGL DOOR 164B COMPUTER TECHNOLOGY 164 FROM EDITING 164B

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 165.1

1 SGL DOOR 165.1 CORRIDOR TO LECTURE RM. 165

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 165.2

1 SGL DOOR 165.2 CORRIDOR TO LECTURE RM. 165

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 166

1 SGL DOOR 166 CORRIDOR TO COMPUTER STUDIES 166

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 167.1

1 SGL DOOR 167.1 CORRIDOR FROM COMPUTER ENGINEERING 167

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 167.2

1 SGL DOOR 167.2 COMPUTER TECHNOLOGY 164 TO COMPUTER ENGINEERING 167

° RH

900 x 2150 x 44 HMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INSTITUTION LOCK	175DW X E7 X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 168.1

1 SGL DOOR 168.1 CORRIDOR TO COMPUTER STUDIES 168

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 168.2

1 SGL DOOR 168.2 COMPUTER STUDIES 166 TO COMPUTER STUDIES 168

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INSTITUTION LOCK	175DW X E7 X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 169.1

1 SGL DOOR 169.1 CORRIDOR FROM COMPUTER TECH. LAB 169

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 169.2

1 SGL DOOR 169.2 COMPUTER ENGINEERING 167 TO COMPUTER TECH. LAB 169

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INSTITUTION LOCK	175DW X E7 X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 169B

1 SGL DOOR 169B COMPUTER TECH. LAB 169 TO STORE 169B

° LH

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 170.1

1 SGL DOOR 170.1 CORRIDOR TO COMPUTER STUDIES 170

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 170.2

1 SGL DOOR 170.2 COMPUTER STUDIES 170 TO COMPUTER STUDIES 168

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INSTITUTION LOCK	175DW X E7 X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 171

1 PR DOORS 171 CORRIDOR FROM AUTOMOTIVE 171

° LHR,RHR

900/900 x 2150 x 44 HMD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

6	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
2	FLUSH BOLT	282D	US26D	HAG
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
2	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 171A

1 SGL DOOR 171A AUTOMOTIVE 171 TO STORE 171A

° RH

900 x 2150 x 44 HMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM
1	STOREROOM LOCK	175F X E7 X G3
1	CYLINDER	20J200V1-26-DQM (AB,F)
1	WALL STOP	GSH 240

26D	MCK
26D	MRK
626	G&A
C32D	GAL

Heading # 172

1 SGL DOOR 172 CORRIDOR FROM CUST. RM 172

° RHR

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	STOREROOM LOCK	175F X E7 X G3
1	CYLINDER	20J200V1-26-DQM (AB,F)

26D	MRK
626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 173

1 PR DOORS 173 CORRIDOR FROM CUST. SERVICES 173

° LHR,RHR

900/900 x 2150 x 44 HMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

6	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM
1	FLUSH BOLT, AUTOMATIC, EXTENSION	FB31P-12-MD
1	STOREROOM LOCK	175F X E7 X G3
1	CYLINDER	20J200V1-26-DQM (AB,F)
1	COORDINATOR, BAR	2040-622
2	CLOSER	4040XP.RWPA.689
2	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM
2	WALL STOP	GSH 240

26D	MCK
US32D	IVE
26D	MRK
626	G&A
622	DON
689	LCN
C32D	GAL
C26D	GAL

Heading # 173A

1 PR DOORS 173A CUST. SERVICES 173 FROM CUST. RM 173A

° LHR,RHR

0/0 x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	STOREROOM LOCK	175F X E7 X G3
1	CYLINDER	20J200V1-26-DQM (AB,F)

26D	MRK
626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 173B

1 SGL DOOR 173B CUST. RM 173C TO CUST. RM 173B

° LH

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1 ENTRY LOCK 175AB X E7 X G3
1 CYLINDER 20J200V1-26-DQM (AB,F)

26D MRK
626 G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 173C

1 SGL DOOR 173C CUST. SERVICES 173 TO CUST. RM 173C

° LH

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1 ENTRY LOCK 175AB X E7 X G3
1 CYLINDER 20J200V1-26-DQM (AB,F)

26D MRK
626 G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 173D

1 SGL DOOR 173D CUST. SERVICES 173 TO CUST. RM 173D

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3 HINGE, 4 1/2, STD WT MPB79 114MM X 102MM
1 ENTRY LOCK 175AB X E7 X G3
1 CYLINDER 20J200V1-26-DQM (AB,F)
1 OVERHEAD STOP 904S
1 CLOSER 4040XP.RWPA.689
1 KICK PLATE GSH 80A X 2-SIDED TAPE X 203MM X 860MM

26D MCK
26D MRK
626 G&A
US32D GLY
689 LCN
C32D GAL

Heading # 173E

1 SGL DOOR 173E CUST. RM 173D TO MEN W/R 173E

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3 HINGE, 4 1/2, STD WT MPB79 114MM X 102MM
1 PRIVACY SET 175L X E7
1 WALL STOP GSH 240

26D MCK
26D MRK
C32D GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 173F

1 SGL DOOR 173 F CUST. RM 173D TO WOMEN W/R 173F

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3 HINGE, 4 1/2, STD WT MPB79 114MM X 102MM
1 PRIVACY SET 175L X E7
1 WALL STOP GSH 240

26D MCK
26D MRK
C32D GAL

Heading # 173G

1 SGL DOOR 173G CUST. RM 173D TO HEAD CUST. 173G

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3 HINGE, 4 1/2, STD WT MPB79 114MM X 102MM
1 ENTRY LOCK 175AB X E7 X G3
1 CYLINDER 20J200V1-26-DQM (AB,F)
1 OVERHEAD STOP 904S
1 KICK PLATE GSH 80A X 2-SIDED TAPE X 203MM X 860MM

26D MCK
26D MRK
626 G&A
US32D GLY
C32D GAL

Heading # 173H

1 SGL DOOR 173H CUST. SERVICES 173 TO ENGINE. RM. 173H

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3 HINGE, 4 1/2, STD WT MPB79 114MM X 102MM
1 STOREROOM LOCK 175F X E7 X G3
1 CYLINDER 20J200V1-26-DQM (AB,F)
1 CLOSER 4040XP.RWPA.689
1 WALL STOP GSH 240

26D MCK
26D MRK
626 G&A
689 LCN
C32D GAL

Heading # 174

1 SGL DOOR 174 CORRIDOR TO CLASSROOM 174

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3 HINGE, 4 1/2, STD WT MPB79 114MM X 102MM
1 INTRUDER LOCKSET 195DB X G3
2 CYLINDER 20J200V0-26-DQM (DB,S)
1 KICK PLATE GSH 80A X 2-SIDED TAPE X 203MM X 860MM
1 WALL STOP GSH 240

26D MCK
26D MRK
626 G&A
C32D GAL
C26D GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 175.1

1 SGL DOOR 175.1 CORRIDOR FROM ART RM. 175

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 175.2

1 SGL DOOR 175.2 CORRIDOR FROM ART RM. 175

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 176

1 SGL DOOR 176 CORRIDOR TO COMPUTER LAB 176

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 177.1

1 SGL DOOR 177.1 CORRIDOR TO PERFORMING ARTS MUSIC KEY BD. 177

° LH

915 x 2135 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 177.2

1 SGL DOOR 177.2 TO PERFORMING ARTS MUSIC KEY BD. 177

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 178.1

1 SGL DOOR 178.1 CORRIDOR TO

° RH

915 x 2135 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C32D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 178.2

1 SGL DOOR 178.2 FROM PERFORMING ARTS 178

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 178A

1 SGL DOOR 178A PERFORMING ARTS 178 FROM 178A

° RHR

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 178B

1 SGL DOOR 178B PERFORMING ARTS 178 TO STORAGE 178B

° LH

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 178C

1 SGL DOOR 178C TO PRACTICE I 178C

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	PRIVACY SET	175L X E7	26D	MRK
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 178D

1 SGL DOOR 178D TO PRACTICE II 178D

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	PRIVACY SET	175L X E7	26D	MRK
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 178E

1 SGL DOOR 178E TO STORAGE 178E

° RH

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 179

1 SGL DOOR 179 CORRIDOR FROM STORAGE 4 179

° LHR

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 179A

1 SGL DOOR 179A STORAGE 4 179 FROM STORAGE 179A

° LHR

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 180.1

1 SGL DOOR 180.1 CORRIDOR FROM HAIR STYLING 180

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 180.2

1 SGL DOOR 180.2 CORRIDOR FROM HAIR STYLING 180

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 180.3

1 SGL DOOR 180.3 HAIR STYLING 180 TO STORAGE 180A

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY

Heading # 180A

1 PR DOORS 180A FROM STORAGE 180A

° LHR,RHR

0/0 x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 181.1

1 SGL DOOR 181.1 CORRIDOR FROM FOOD SERVICES 181

° LHR

965 x 2150 x 44 HMD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 925MM	C32D	GAL
1	DROP PLATE	4040XP-18G.689	689	LCN

Heading # 181.2

1 SGL DOOR 181.2 CORRIDOR FROM FOOD SERVICES 181

° RHR

965 x 2150 x 44 HMD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 925MM	C32D	GAL
1	DROP PLATE	4040XP-18G.689	689	LCN

Heading # 181.3

1 SGL DOOR 181.3 FOOD SERVICES 181 FROM SEMINAR II 119B

° LHR

1100 x 2150 x 44 HMD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INSTITUTION LOCK	175DW X E7 X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 925MM	C32D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 182.1

1 SGL DOOR 182.1 CORRIDOR FROM PERFORMING ARTS DRAMA 2 182

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	CLOSER	4040XP.RWPA.689	689	LCN
1	WALL STOP	GSH 240	C32D	GAL

Heading # 182.2

1 SGL DOOR 182.2 CORRIDOR FROM PERFORMING ARTS DRAMA 2 182

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	CLOSER	4040XP.RWPA.689	689	LCN
1	WALL STOP	GSH 240	C32D	GAL

Heading # 182.3

1 SGL DOOR 182.3 FROM PERFORMING ARTS DRAMA 2 182

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	PASSAGE SET	175N X E7	26D	MRK
1	WALL STOP	GSH 240	C26D	GAL

Heading # 182A.1

1 SGL DOOR 182A.1 CORRIDOR TO STORAGE 182A

° LH

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 182A.2

1 PR DOORS 182A.2 CAFETORIUM 4 182B FROM STORAGE 182A	°	LHR,RHR		
0/0 x ex. x XHMD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
1 CYLINDER 10J0200-26-DQM (MORTISE CYLINDER)			626	MED
NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.				
CYLINDER REQUIRED TO BE CONFIRMED				

Heading # 182B.1

1 PR DOORS 182B.1 CORRIDOR FROM CAFE 4 182B	°	LHR,RHR		
0/0 x ex. x XHMD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
6 HINGE, 4 1/2, STD WT MPB79 114MM X 102MM			26D	MCK
1 MULLION L980 X 120			PC	SAR
2 RIM EXIT DEVICE 16-8810F 900MMW X NO TRIM X 649 (DEVCYL-NONE)			US32D	SAR
5 CYLINDER 10J0200-26-DQM-Z20			26	MED
2 OVERHEAD STOP 904S			US32D	GLY
2 CLOSER 4040XP.RWPA.689			689	LCN
2 DROP PLATE 4040XP-18G.689			689	LCN

Heading # 182B.2

1 PR DOORS 182B.2 CORRIDOR FROM CAFE 4 182B	°	LHR,RHR		
0/0 x ex. x XHMD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
6 HINGE, 4 1/2, STD WT MPB79 114MM X 102MM			26D	MCK
1 MULLION L980 X 120			PC	SAR
2 RIM EXIT DEVICE 16-8810F 900MMW X NO TRIM X 649 (DEVCYL-NONE)			US32D	SAR
5 CYLINDER 10J0200-26-DQM-Z20			26	MED
2 OVERHEAD STOP 904S			US32D	GLY
2 CLOSER 4040XP.RWPA.689			689	LCN
2 DROP PLATE 4040XP-18G.689			689	LCN

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 182B.3

1 PR DOORS 182B.3 CORRIDOR FROM CAFE 4 182B

° LHR,RHR

0/0 x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

6	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	MULLION	L980 X 120	PC	SAR
2	RIM EXIT DEVICE	16-8810F 900MMW X NO TRIM X 649 (DEVCYL-NONE)	US32D	SAR
5	CYLINDER	10J0200-26-DQM-Z20	26	MED
2	OVERHEAD STOP	904S	US32D	GLY
2	CLOSER	4040XP.RWPA.689	689	LCN
2	DROP PLATE	4040XP-18G.689	689	LCN

Heading # 182B.4

1 PR DOORS 182B.4 CORRIDOR FROM CAFE 4 182B

° LHR,RHR

0/0 x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

6	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	MULLION	L980 X 120	PC	SAR
2	RIM EXIT DEVICE	16-8810F 900MMW X NO TRIM X 649 (DEVCYL-NONE)	US32D	SAR
5	CYLINDER	10J0200-26-DQM-Z20	26	MED
2	OVERHEAD STOP	904S	US32D	GLY
2	CLOSER	4040XP.RWPA.689	689	LCN
2	DROP PLATE	4040XP-18G.689	689	LCN

Heading # 182C

1 SGL DOOR 182C KITCHEN 182F TO MECHANICAL 182C

° LH

ex. x ex. x XHMD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 182D

1 SGL DOOR 182D KITCHEN 182F TO W/R 182D

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM		
1	PASSAGE SET	175N X E7	26D	MCK
1	INDICATOR DEADBOLT	D271 X 30-253 X 10-094	26D	MRK
1	WALL STOP	GSH 240	626	FAL
			C32D	GAL

Heading # 182E.1

1 SGL DOOR 182E.1 KITCHEN 182F TO SERVERY 182E

° RH

ex x ex x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 182E.2

1 SGL DOOR 182E.2 KITCHEN 182F TO SERVERY 182E

° LH

ex x ex x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 182E.3

1 SGL DOOR 182E.3 SERVERY 182E FROM CAFETORIUM 4 182B

° LHR

ex. x ex. x XHMD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 182E.4

1 SGL DOOR 182E.4 SERVERY 182E FROM CAFETORIUM 4 182B

° LHR

ex. x ex. x XHMD Door/ XHMF Frame

45 MIN Door/45 MIN Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 182E.5

1 SGL DOOR 182E.5 SERVERY 182E FROM CAFETORIUM 4 182B			°	RHR
ex. x ex. x XHMD Door/ XHMF Frame				45 MIN Door/45 MIN Frame
1 STOREROOM LOCK	175F X E7 X G3		26D	MRK
1 CYLINDER	20J200V1-26-DQM (AB,F)		626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 182E.6

1 SGL DOOR 182E.6 SERVERY 182E FROM CAFETORIUM 4 182B			°	RHR
ex. x ex. x XHMD Door/ XHMF Frame				45 MIN Door/45 MIN Frame
1 STOREROOM LOCK	175F X E7 X G3		26D	MRK
1 CYLINDER	20J200V1-26-DQM (AB,F)		626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 182F

1 SGL DOOR 182 F CORRIDOR FROM KITCHEN 182F			°	RHR
ex. x ex. x XHMD Door/ XHMF Frame				45 MIN Door/45 MIN Frame
1 STOREROOM LOCK	175F X E7 X G3		26D	MRK
1 CYLINDER	20J200V1-26-DQM (AB,F)		626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 182H

1 PR DOORS 182H CAFETORIUM 182B TO STORAGE 182H			°	LH,RH
0/0 x ex. x XHMD Door/ XHMF Frame				45 MIN Door/45 MIN Frame
1 STOREROOM LOCK	175F X E7 X G3		26D	MRK
1 CYLINDER	20J200V1-26-DQM (AB,F)		626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 183

1 SGL DOOR 183 CORRIDOR TO MECH. RM. 183			°	RH
ex. x ex. x XHMD Door/ XHMF Frame				NON-RTD Door/NON-RTD Frame
1 STOREROOM LOCK	175F X E7 X G3		26D	MRK
1 CYLINDER	20J200V1-26-DQM (AB,F)		626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 183A

1 SGL DOOR 183A MECH. RM. 183 TO 183A			°	LH
ex. x ex. x XHMD Door/ XHMF Frame				NON-RTD Door/NON-RTD Frame
1 STOREROOM LOCK	175F X E7 X G3		26D	MRK
1 CYLINDER	20J200V1-26-DQM (AB,F)		626	G&A
NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.				

Heading # 184

1 SGL DOOR 184 CORRIDOR TO STORAGE 5 184			°	LH
ex. x ex. x XHMD Door/ XHMF Frame				NON-RTD Door/NON-RTD Frame
1 STOREROOM LOCK	175F X E7 X G3		26D	MRK
1 CYLINDER	20J200V1-26-DQM (AB,F)		626	G&A
NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.				

Heading # 185

1 SGL DOOR 185 CORRIDOR FROM ELEC. RM. 185			°	LHR
ex. x ex. x XHMD Door/ XHMF Frame				NON-RTD Door/NON-RTD Frame
1 STOREROOM LOCK	175F X E7 X G3		26D	MRK
1 CYLINDER	20J200V1-26-DQM (AB,F)		626	G&A
NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.				

Heading # 186.1

1 SGL DOOR 186.1 CORRIDOR FROM VISUAL ARTS STUDIO 2 186			°	RHR
900 x 2150 x 44 WD Door/ XHMF Frame				NON-RTD Door/NON-RTD Frame
3 HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM		26D	MCK
1 INTRUDER LOCKSET	195DB X G3		26D	MRK
2 CYLINDER	20J200V0-26-DQM (DB,S)		626	G&A
1 OVERHEAD STOP	904S		US32D	GLY
1 KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM		C32D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 186.2

1 SGL DOOR 186.2 CORRIDOR FROM VISUAL ARTS STUDIO 2 186

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 186A

1 SGL DOOR 186A VISUAL ARTS STUDIO 2 186 TO STORAGE 186A

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY

Heading # 186B

1 SGL DOOR 186B VISUAL ARTS STUDIO 2 186 TO KILN 186B

° LH

900 x 2150 x 44 HMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 188.1

1 SGL DOOR 188.1 CORRIDOR TO WOMEN W/R 188

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	CYLINDER	20J009S4-26-DQM	26D	MED
1	CLASSROOM DEADBOLT	B663.B.626.12-631	626	SAN
1	PUSH PLATE	GSH 81A X 2-SIDED TAPE X 127MM X 508MM	C32D	GAL
1	PULL	4609-1 X THROUGH BOLT MOUNTING	C32D	GAL
1	PULL	GSH 981 X #2	C32D	GAL
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 188.2

1 SGL DOOR 188.2 CORRIDOR TO WOMEN W/R 188

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	CYLINDER	20J009S4-26-DQM	26D	MED
1	CLASSROOM DEADBOLT	B663.B.626.12-631	626	SAN
1	PUSH PLATE	GSH 81A X 2-SIDED TAPE X 127MM X 508MM	C32D	GAL
1	PULL	4609-1 X THROUGH BOLT MOUNTING	C32D	GAL
1	PULL	GSH 981 X #2	C32D	GAL
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 189.1

1 SGL DOOR 189.1 CORRIDOR FROM

° RHR

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 189.2

1 SGL DOOR 189.2 CORRIDOR FROM			°	LHR
ex. x ex. x XHMD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.				

Heading # 190.1

1 SGL DOOR 190.1 CORRIDOR TO MEN W/R 190			°	LH
900 x 2150 x 44 WD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	CYLINDER	20J009S4-26-DQM	26D	MED
1	CLASSROOM DEADBOLT	B663.B.626.12-631	626	SAN
1	PUSH PLATE	GSH 81A X 2-SIDED TAPE X 127MM X 508MM	C32D	GAL
1	PULL	4609-1 X THROUGH BOLT MOUNTING	C32D	GAL
1	PULL	GSH 981 X #2	C32D	GAL
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 190.2

1 SGL DOOR 190.2 CORRIDOR TO MEN W/R 190			°	RH
900 x 2150 x 44 WD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	CYLINDER	20J009S4-26-DQM	26D	MED
1	CLASSROOM DEADBOLT	B663.B.626.12-631	626	SAN
1	PUSH PLATE	GSH 81A X 2-SIDED TAPE X 127MM X 508MM	C32D	GAL
1	PULL	4609-1 X THROUGH BOLT MOUNTING	C32D	GAL
1	PULL	GSH 981 X #2	C32D	GAL
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 191

1 SGL DOOR 191 CORRIDOR TO PAST. YOUTH 191

° RH

915 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C32D	GAL

Heading # 191A

1 SGL DOOR 191A PAST. YOUTH 191 TO Y.C.A. 191A

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	WALL STOP	GSH 240	C32D	GAL

Heading # 191B

1 SGL DOOR 191B PAST. YOUTH 191 TO CHAPLAIN Y.C.W. 191B

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	WALL STOP	GSH 240	C32D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 192.1

1 SGL DOOR 192.1 CORRIDOR FROM CLASSROOM 192

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 192.2

1 SGL DOOR 192.2 CLASSROOM 192 TO PREP. RM. 193A

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INSTITUTION LOCK	175DW X E7 X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 193

1 SGL DOOR 193 CORRIDOR FROM STORE 193

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	DROP PLATE	4040XP-18G.689	689	LCN

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 193A

1 SGL DOOR 193A STORE 193 TO PREP. RM. 193A

° LH

ex. x ex. x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 194.1

1 SGL DOOR 194.1 CORRIDOR FROM CLASSROOM 194

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP/HOLDER, SURFACE	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 194.2

1 SGL DOOR 194.2 CLASSROOM 194 TO PREP. RM. 193A

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INSTITUTION LOCK	175DW X E7 X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL

Heading # 195

1 SGL DOOR 195 CORRIDOR FROM CLASSROOM 195

° LHR

915 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 874MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 196

1 SGL DOOR 196 CORRIDOR FROM CAREER CENTRE			°	RHR
900 x 2150 x 44 WD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C32D	GAL

Heading # 196B

1 SGL DOOR 196B TO GUID./ RECORDS 196B			°	RH
900 x 2150 x 44 WD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	WALL STOP	GSH 240	C32D	GAL

Heading # 196C

1 SGL DOOR 196C CO-OP EDU. GUI. SERVICES 196F FROM 196C			°	LHR
900 x 2150 x 44 WD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY

Heading # 196D

1 SGL DOOR 196D CO-OP EDU. GUI. SERVICES 196F TO CO-OP OFFICE 196D			°	LH
900 x 2150 x 44 WD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 196E.1

1 SGL DOOR 196E.1 CO-OP OFFICE 196D FROM CO-OP OFFICE 196E			°	RHR
900 x 2150 x 44 WD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	PASSAGE SET	175N X E7	26D	MRK
1	OVERHEAD STOP	904S	US32D	GLY

Heading # 196E.2

1 SGL DOOR 196E.2 CO-OP EDU. GUI. SERVICES 196F FROM CO-OP OFFICE 196E			°	LHR
900 x 2150 x 44 WD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	OVERHEAD STOP	904S	US32D	GLY

Heading # 196F

1 SGL DOOR 196F CORRIDOR FROM CO-OP EDU. GUI. SERVICES 196F			°	LHR
915 x 2150 x 44 WD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 196G

1 SGL DOOR 196G CO-OP EDU. GUI. SERVICES 196F TO GUIDE/ CO-OP 196G			°	RH
900 x 2150 x 44 WD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	WALL STOP	GSH 240	C26D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 196H

1 SGL DOOR 196H CO-OP EDU. GUI. SERVICES 196F TO GUIDE/ CO-OP 196H			°	RH
900 x 2150 x 44 WD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	WALL STOP	GSH 240	C26D	GAL

Heading # 196J

1 SGL DOOR 196J CO-OP EDU. GUI. SERVICES 196F TO GUIDE/ CO-OP 196J			°	LH
900 x 2150 x 44 WD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	WALL STOP	GSH 240	C26D	GAL

Heading # 196K

1 SGL DOOR 196K CO-OP EDU. GUI. SERVICES 196F TO GUIDE/ CO-OP 196K			°	RH
915 x 2150 x 44 WD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	WALL STOP	GSH 240	C26D	GAL

Heading # 196L.1

1 SGL DOOR 196L.1 CO-OP EDU. GUI. SERVICES 196F TO CONFERENCE RM. II 196L			°	RH
900 x 2150 x 44 WD Door/ XHMF Frame			NON-RTD Door/NON-RTD Frame	
3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 196M

1 SGL DOOR 196M CO-OP EDU. GUI. SERVICES 196F TO OFFICE 196M

° RH

915 x 2150 x 44 WD Door/ HMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	ENTRY LOCK	175AB X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	WALL STOP	GSH 240	C32D	GAL

Heading # 197.1

1 SGL DOOR 197.1 CORRIDOR FROM STAFF 2 197

° LHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C32D	GAL

Heading # 197.2

1 SGL DOOR 197.2 CORRIDOR FROM STAFF

° RHR

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	STOREROOM LOCK	175F X E7 X G3	26D	MRK
1	CYLINDER	20J200V1-26-DQM (AB,F)	626	G&A
1	CLOSER	4040XP.RWPA.689	689	LCN
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C32D	GAL

Heading # 197A

1 SGL DOOR 197A STAFF 2 197 TO MEN W/R 197A

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	PRIVACY SET	175L X E7	26D	MRK
1	WALL STOP	GSH 240	C32D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 197B

1 SGL DOOR 197B STAFF 2 197 TO WOMEN W/R 197B

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3 HINGE, 4 1/2, STD WT MPB79 114MM X 102MM
1 PRIVACY SET 175L X E7
1 WALL STOP GSH 240

26D MCK
26D MRK
C32D GAL

Heading # 201

1 SGL DOOR 201 CORRIDOR FROM MACH. RM. 201

° RHR

ex x ex x XHMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

1 STOREROOM LOCK 175F X E7 X G3
1 CYLINDER 20J200V1-26-DQM (AB,F)

26D MRK
626 G&A

NEW LOCK ONLY. EXISTING DOOR AND HARDWARE TO REMAIN.

Heading # 204

1 SGL DOOR 204 CORRIDOR TO STORE 204

° LH

900 x 2150 x 44 HMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3 HINGE, 4 1/2, STD WT MPB79 114MM X 102MM
1 STOREROOM LOCK 175F X E7 X G3
1 CYLINDER 20J200V1-26-DQM (AB,F)
1 CLOSER 4040XP.RWPA.689
1 WALL STOP GSH 240

26D MCK
26D MRK
626 G&A
689 LCN
C32D GAL

Heading # 205

1 SGL DOOR 205 CORRIDOR TO CLASSROOM 205

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3 HINGE, 4 1/2, STD WT MPB79 114MM X 102MM
1 INTRUDER LOCKSET 195DB X G3
2 CYLINDER 20J200V0-26-DQM (DB,S)
1 KICK PLATE GSH 80A X 2-SIDED TAPE X 203MM X 860MM
1 WALL STOP GSH 240

26D MCK
26D MRK
626 G&A
C32D GAL
C26D GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 206

1 SGL DOOR 206 CORRIDOR TO CLASSROOM 206

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 207

1 SGL DOOR 207 CORRIDOR TO CLASSROOM 207

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 208

1 SGL DOOR 208 CORRIDOR TO CLASSROOM 208

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 209

1 SGL DOOR 209 CORRIDOR TO CLASSROOM 209

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 210

1 SGL DOOR 210 CORRIDOR TO CLASSROOM 210

° RH

900 x 2150 x 44 HMD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

Heading # 211

1 SGL DOOR 211 CORRIDOR TO CLASSROOM 211

° LH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

MONSIGNOR DOYLE CSS
185 MYERS ROAD

Heading # 212

1 SGL DOOR 212 CORRIDOR TO CLASSROOM 212

° RH

900 x 2150 x 44 WD Door/ XHMF Frame

NON-RTD Door/NON-RTD Frame

3	HINGE, 4 1/2, STD WT	MPB79 114MM X 102MM	26D	MCK
1	INTRUDER LOCKSET	195DB X G3	26D	MRK
2	CYLINDER	20J200V0-26-DQM (DB,S)	626	G&A
1	KICK PLATE	GSH 80A X 2-SIDED TAPE X 203MM X 860MM	C32D	GAL
1	WALL STOP	GSH 240	C26D	GAL

ADDENDUM NO. 01

Attention: Sonia Diaz

Address: 17/21 Architects
1065 Valetta St., Suite A,
London, ON

Date: February 28, 2024

Project #: CE-5800

Project: Monsignor Doyle CSS
185 Myers Rd.,
Cambridge, ON

Cc. ---

Please amend the drawings and specifications for the above noted project as described below. Identify this addendum on the tender form to insure a complete tender form.

1. MECHANICAL

1.1. Provide mixing valve as shown in plumbing fixture schedule below.

TMV	WATTS MODEL LFMM431 HYDROGUARD XP MASTER TEMPERING VALVE WITH PARAFIN-BASED, THERMAL ACTUATION TECHNOLOGY, DIRT AND LIME RESISTANT POPPET AND SEAT DESIGN, VALVE CHECKSTOPS, VANDAL-RESISTANT LOCKING MECHANISM RO SECURE TEMPERATURE SETTING, AND A ROUGH BRONZE FINISH. VALVE LISTED TO ASSE 1017 AND CERTIFIED TO CSA B125. SUITABLE FOR FLOWS 3.0GPM TO 20GPM. VERIFY EXISTING PIPE SIZES ON SITE.
-----	--

END OF ADDENDUM No. 01

WE MAKE BUILDINGS WORK

LONDON
9-1385 NORTH ROUTLEDGE PARK
LONDON, ON N6H 5N5
T 519 472 7640

E info@callidus.ca

KINGSTON
1471 JOHN COUNTER BLVD.,
UNIT 301, KINGSTON, ON. K7M 8S8
T 613 900 0845

W www.callidus.ca

KITCHENER
210-137 GLASGOW STREET,
OFFICE 141, KITCHENER, ON. N2G 4X8
T 519 472 7640