

PANEL DP-X

1	SPARE 100A	2	North Hall Panel 100A
3		4	
5	West Hall Alcove Panel 100A	6	East Class Panel LP-1 100A
7		8	
9		10	
11		12	
13	Hall Panel by Office 150A	14	
15		16	
17		18	
19		20	Gym Panel 'G' 100A
21		22	
23		24	
25		26	
27	Existing Load 200A	28	
29		30	
31		32	
33		34	
35		36	
37		38	
39		40	
41		42	

PANEL 'G'

1	Exit Lighting	2	Gym T-Slot Receptacle 20A
3	DC Pack #1 / W/R, Storage Rm & C.R Lighting 20A	4	Gym T-Slot Receptacle 20A
5	DC Pack #2 / Gym Lighting 20A	6	Gym T-Slot Receptacle 20A
7	Exterior Lighting	8	Gym Fans (West)
9	Fire Smoke Damper	10	Gym Fans (East)
11	Storage Rooms Receptacles	12	Basketball Net Motor (West) 20A
13	CR 138 Receptacles & Plumbing Equipment	14	Basketball Net Motor (East) 20A
15	CR 137 Receptacles & Plumbing Equipment	16	Maintenance T-Slot Receptacle 20A
17	W/R 135 Receptacles & Plumbing Equipment	18	Scoreboard 20A
19	W/R 134 Receptacles & Plumbing Equipment	20	Projection Screen
21	SPARE	22	Vestibule V-4 Fan Heater
23	Door Operator 20A	24	
25	Fire Shutter	26	Storage Room Unit Heater 30A
27	EF-1	28	
29	EF-3	30	WR 134 BB Heater
31	WR 135 BB Heater	32	
33		34	Gym Shade Motor 20A
35	Trap Primer	36	Folding Partition 20A
37	Ploe Lighting	38	SPARE 20A
39	Changeroom Hand Dryer	40	SPARE 20A
41	SPARE	42	SPACE

PANEL LP-A

1	Hot Water Tank 30A	2	Sump Pump 15A
3		4	Existing Load 15A
5	Program Fan Timer 15A	6	Gym E/F Heating Relay 20A
7	Kitchen Plug 15A	8	Dishwasher 15A
9	Fire Monitoring 15A	10	Staff RM 129 T-SLOT Rec. 20A
11	Catwalk Plug 15A	12	Heat Pump #3 15A
13	Boiler 15A	14	Caretakers Plug 15A
15	Boiler Control Panel 15A	16	Microwave Rec. 15A
17	Existing Load 15A	18	Microwave Rec. 15A
19	Pressure Valve Boiler RM 15A	20	Heating Control K.Garden 15A
21	Existing Load 15A	22	
23	Existing Load 15A	24	E/F Girl's Washroom 15A
25	Dishwasher in Staff RM 20A	26	Honeywell Control 15A
27	Existing Load 15A	28	Existing Load 15A
29	Existing Load 15A	30	Existing Load 15A
31	Existing Load 15A	32	Circ. Pump 15A
33	Existing Load 15A	34	Existing Load 15A
35	Existing Panel LP-B 100A	36	Plug 15A
37		38	Existing Load 30A
39		40	
41		42	

PANEL LP-B

1	Boiler 1 20A	2	Boiler 2 20A
3		4	
5	Pump Boiler 1 15A	6	Pump Boilder 2 15A
7	Existing Load 20A	8	Existing Load 20A
9	Existing Load 20A	10	Control Box 15A
11	Existing Load 20A	12	Existing Load 15A
13	Existing Load 20A	14	Existing Load 20A
15	Existing Load 15A	16	
17	Existing Load 15A	18	Existing Load 20A
19	EF-2 15A	20	
21		22	Existing Load 20A
23		24	
25		26	Staff RM 129 Fridge Rec. 15A
27		28	Staff RM 129 Fridge Rec. 15A
29		30	Staff RM 129 Fridge Rec. 15A
31		32	
33		34	
35		36	
37		38	
39		40	
41		42	