



www.esasafe.com

400 Sheldon Dr, Unit 1, Cambridge, ON, N1T 2H9
Toll Free Tel: 1-877-372-7233 Toll Free Fax: 1-800-667-4278
esa.cambridge@electricalsafety.on.ca

Requested Inspection Outcome Summary Report

B-SAFE ELECTRIC LTD

1-5080 TIMBERLEA BLVD

MISSISSAUGA ON

L4W 4M2

| | |
|--------------|--------------|
| Notice Date: | May 19, 2025 |
| Print Date: | May 19, 2025 |
| Customer ID: | 6853 |

Telephone: (905)872-7233

Fax: (905)624-6012

Email:

| Notification | Inspection Type | Status | Site Address | Cust. Order # |
|--------------|-----------------|--------|---|---------------|
| 18480991 | Final Requested | PASSED | GLENVIEW PUBLIC SCHOOL 143 TOWNSEND AVE BURLINGTON ON L7T 1Z1 | 12402 |



400 Sheldon Dr, Unit 1, Cambridge, ON, N1T 2H9
Toll Free Tel: 1-877-372-7233 Toll Free Fax: 1-800-667-4278
esa.cambridge@electricalsafety.on.ca

Certificate of Acceptance

B-SAFE ELECTRIC LTD

1-5080 TIMBERLEA BLVD

MISSISSAUGA ON

L4W 4M2

Telephone: (905)872-7233

Fax: (905)624-6012

Email:

| | |
|----------------------|--------------|
| Notice Date: | May 16, 2025 |
| Notification Number: | 18480991 |
| Print Date: | May 16, 2025 |
| Customer ID: | 6853 |
| Licence Number: | 7005848 |
| Cust. Order: | 12402 |

RE

GLENVIEW PUBLIC SCHOOL

143 TOWNSEND AVE

BURLINGTON ON L7T 1Z1

We hereby certify that the electrical installation at the aforementioned address, and as described herein, is accepted in accordance with the requirements of the Ontario Electrical Safety Code.

Locations: GYM

| Work Item | Description | Quantity |
|-----------|---|----------|
| 1 | TRENCH INSPECTION Primary/Secondary Separate 1.000 | 1 |
| 2 | OUTLETS AND OTHER DEVICES Parking Lot Lights 2.000 Receptacles 46.000 Fixtures 50.000 Switches 10.000 Exit/Emergency Signs 17.000 Fractional HP Motors 4.000 GFCIs 6.000 Heat/Cook Device <=5KW 2.000 | 137 |
| 3 | FIRE ALARM DEVICES Heat/Smoke/CO Detectors 12.000 Annunciator Panel 2.000 Pull Stations 4.000 Strobe Lights 9.000 | 27 |
| 4 | LV DISTRIBUTION EQUIPMENT - 100 AMPS Panelboards 1.000, 100 AMPS Panelboards 1.000, 15 AMPS | 2 |
| 5 | LV MISCELLANEOUS EQUIPMENT - 1.00 HP Motors >=1HP 2.000, 1.00 HP Rooftop Units 1.000 | 3 |

The Electrical Safety Authority (ESA) operates as a delegated authority on behalf of the provincial government in accordance with Part VIII , section 113 of the Electricity Act, 1998, S.O. 1998, c.15, Sched. A.(the Act), and the Safety and Consumer Statutes Administration Act, 1996, S.O. 1996, c.19. ESA's mandate is to administer the Act and corresponding Regulations on behalf of the Province of Ontario.

ESA is a not-for-profit corporation under the direction and control of a Board of Directors and is accountable to the Ministry of Public and Business Service Delivery and Procurement in accordance with an Administrative Agreement.

—

—
—
—