



Halton District School Board

Addendum No. 4

RFT 26-035 - School Renovations - Kilbride Public School

The following, issued by the Halton District School Board (HDSB) February 10, 2026, shall be incorporated in the specifications and shall form part of the proposal document for the above.

REVISED DATES:

The procurement **closing date** has been **amended**. This Request for Tender will now **close on or before 2:00 p.m.** via email to chatelaina@hdsb.ca on **February 19, 2026**.

ATTACHED:

Bidders are asked to refer to the attached Addendum No. 4 as drafted by The Ventin Group Ltd. (+VG Architects). (2 page)

RECEIPT OF ADDENDA MUST BE ACKNOWLEDGED ON THE FORM OF QUOTATION.

**PAGE 1 OF 3
END OF ADDENDUM 4**

KILBRIDE ELEMENTARY SCHOOL RENOVATION
6611 PANTON ST, BURLINGTON, ON L7P 0L8
HALTON DISTRICT SCHOOL BOARD
ADDENDUM NO. 4
FEBRUARY 10, 2026

Page 1 of 1

The following additional instructions shall apply to and govern the tender documents.

QUESTIONS AND ANSWERS

- Q1 BAS Controls: Please confirm if there is an existing Building Automation System (BAS) in place. If so, who is the approved controls contractor for the facility? –
- A1 An existing **Building Automation System (BAS)** is in place at the facility. The approved BAS controls contractor is **HTS Controls**.
- Q2 Mechanical Specs: Please provide the mechanical specifications, specifically the plumbing fixture schedule.
- A2 Please refer to Addendum #1
- Q3 Bid Extension: Can this tender be extended by a week?
- A3 The new closing date is February 19. Time and mode of submission remain the same.

AMENDMENT NO1. – REVISIONS/ CLARIFICATIONS TO ARCHITECTURAL DRAWINGS

- Door assembly D17 for new universal washroom is to be MIN fire rated. No Glass. Only requires HM panels.
- All glass in new door assemblies shall be **tempered safety glass**, unless otherwise required by code or noted on the drawings.

AMENDMENT NO 2. – REVISIONS TO MECHANICAL AND ELECTRICAL SPECIFICATIONS

- Refer to attached Mechanical Addendum #1

ATTACHMENT

- Mechanical Addendum #1

End of Addendum #4

This communication is intended as a private communication for the sole use of the primary addressee and those individuals listed for copies in the original message. The information contained in this communication is private and confidential and if you are not an original intended recipient you are hereby notified that copying, forwarding or other dissemination or distribution of this communication by any means is prohibited. If you are not specifically authorized to receive this communication and if you believe that you received it in error, please notify the original sender immediately. This is proprietary to +VG Architects (The Ventin Group Ltd.)

50 Dalhousie Street, Brantford, Ontario N3T 2H8 | T: 519.754.1652

52 Scarsdale Road, Suite 212, Toronto, Ontario M3B 2R7 | T: 416.588.6370

1340 Wellington Street West, Ottawa, Ontario K1Y 3B7 | T: 613.680.5557



Mechanical Addendum No. 1

EXP Project: ALL-25001986-A0 - HDSB Kilbride Public School Renovation

Date: February 10, 2026

Prepared By: EXP Services Inc.

Requirements:

The addendum forms part of the Contract Documents and amends the original Specifications and Drawings, as noted below.

Ensure that all parties submitting bids are aware of all items included in this Addendum.

This Addendum consists of 1 page.

Mechanical Questions

- Q. **Please provide the mechanical specifications, specifically the plumbing fixture schedule.**
- A. Refer to the mechanical specification issued under project addendum #1 specifically, section 22 42 02 – Plumbing Fixtures.