



**Waterloo Catholic
District School Board**

ADDENDUM # 002

**St Anne Cambridge CES Renovation
127 Elgin St N, Cambridge, ON N1R 0E1
RFT No. 2026-11**

17/21 Project No 2527

Documents prepared by:

17|21 architects inc.
1065 Valetta Street, Suite A
London, Ontario
N6H 2Z9

Issue Date:

Thursday, 12 March 2026

This addendum forms part of the Contract Documents and amends the original drawings dated March 3rd, 2026 marked as ISSUED FOR TENDER and specifications dated March 3rd, 2026

TABLE OF CONTENTS

ADDENDUM # 1 (Including cover)

5 Page(s)

TOTAL PAGE COUNT FOR THIS ADDENDUM

5 Page(s)

PART A- GENERAL

1- Questions:


Question #1:

Further clarification for Electrical (Division 16):

3) Please provide the make and model of switchboard PP1 located in the basement

Answer:

The existing switchboard is a federal pioneer CDP unit - 800amp/120/208v 3phase 4 wire.



Question #2:

Request for clarification for Electrical (Division 16) items:

- 1- What is the make and model of panel LP-H, Panel A, LP-J?
- 2- Where is the basement in relevance to the ground floor plans?

Answer:

- 1- LP-H - Square D - NC5-SHR - see pic
A - Federal Pioneer - NBLP42B-4LSB - see pic
LP-J - Square D - NQ430L2C - see pic

Pictures below



PART B- SPECIFICATIONS

- **Section 09 91 00 – Painting:** 1.2 Quality Assurance, point .4:

Change:

.4 Inspection:

- .1 A painting inspector may be appointed by the Consultant in order to provide independent inspection of all painting and testing where required.
- .2 The inspector shall review the condition of the substrate prior to application of any paint. The inspector shall review all painting applications in accordance with a predetermined plan agreed upon by the painting contractor, the painting inspector, and the Consultant.
- .3 The painting inspector shall be acceptable to the Architect and the OPCA Association. The cost for the inspection reports shall be paid from the Inspection and Testing Allowance.

To:

.4 Examination:

- 1- Investigate existing substrates for problems related to proper and complete preparation of surfaces to be painted. Report damages, defects, unsatisfactory or unfavourable conditions to Consultant before proceeding with work.

PART C – ARCHITECTURAL DRAWINGS

- RESERVED

PART D – MECHANICAL / ELECTRICAL DRAWINGS

- RESERVED

END OF ADDENDUM # 002