



**Addendum # 2**  
**Bid Opportunity: 26-7851-RFT**  
**Crestview Public School**  
**RAAC Roof Deck Replacement/ Interior Alterations**  
**Closing Date: Wednesday, April 1, 2026, 2:00 PM**

---

The following issued by the Board shall form part of the Bid/ Proposal Solicitation document. The revisions and additions noted herein along with any attachments shall be read in conjunction with all other related documents. This Addendum shall take precedence over the previously issued documents where differences occur. Receipt of this addendum must be acknowledged in the Bidding System, bids & tenders.

If you have already submitted a Bid/ Proposal, it will be automatically withdrawn as a result of this addendum. You must resubmit the Bid/ Proposal acknowledging all addenda and revising your Bid/ Proposal to comply with all addenda.

## 2.1 QUESTIONS/ ANSWERS

### **Question 1:**

Is there any want or need for a new pot feeder and micro filter or is the existing chemical treatment adequate.

### **Answer 1:**

The replacement of the existing pot feeder/filter is not required for this project.

### **Question 2:**

Most of the cabinet heaters are to be removed and reused. With most of them being semi recessed in block walls can they be protected during construction as trying to remove them will likely damage them.

### **Answer 2:**

Contractor is to protect cabinet heaters during construction if recessed. The Contractor is responsible for replacing the heater if damage occurs.

### **Question 3:**

M3.4 note says to clean and paint grilles in millwork. We didn't notice any grilles in the millwork at the site visit. Please provide more info on the requirements.

### **Answer 3:**

Refer to Item 2.2 below.

## 2.2 MECHANICAL

**.1 REFER TO THE ATTACHED MECHANICAL ADDENDUM 1 (PART OF THIS ADDENDUM NO. 2) PREPARED BY DEI CONSULTING ENGINEERS, DATED MARCH 30, 2026 (1 PAGE).**

**.2 THIS ADDENDUM CONSISTS OF:**

**.1 MECHANICAL SUMMARY OF CHANGES (1 PAGE)**

END OF ADDENDUM #2  
+ Mechanical Addendum 1 (1 page)

March 30, 2026

Client: Cornerstone Architecture Incorporated  
102-320 Thomas Street  
London, ON N6A 0E1

RE: Crestview Public School – RAAC Ph1 Reno  
Kitchener, ON

Job #: 26012

Attn: Alison Hannay, Principal, BES Barch OAA MRAIC LEED®AP (BD+C)

---

## ADDENDUM 01

### MECHANICAL

#### Item 1

- 1.0 Reference Drawing M2.4 and M3.4
  - .1 In existing Classroom 1 to Classroom 12, remove millwork grille scope from project.

### ELECTRICAL

#### Item 1

- 1.0 No electrical content.

Steve Oatley  
Lead Designer, Partner  
26012 Addendum 01 (M-Classrooms 1-12 Millwork Grille) Mar 30 26  
nt/ma