



Waterloo Catholic District School Board

ADDENDUM # 006

St Peter CES Renovation 92 Avenue Rd, Cambridge, ON N1R 1C1 RFT No. 2026-13

17/21 Project No 2528

Documents prepared by:

17|21 architects inc.
1065 Valetta Street, Suite A
London, Ontario
N6H 2Z9

Issue Date:

Monday, 23 March 2026

This addendum forms part of the Contract Documents and amends the original drawings dated March 4th, 2026 marked as ISSUED FOR TENDER and specifications dated March 4th, 2026

TABLE OF CONTENTS

ADDENDUM # 6 (Including cover) 2 Page(s)

TOTAL PAGE COUNT FOR THIS ADDENDUM	2 Page(s)
------------------------------------	-----------

PART A- GENERAL

Clarification:

Elevations indicated A050 for the new 8inch sanitary line: Sanitary pipe elevation are not consistent with grade elevations. General contractor to assume that sanitary line is 1.8mt below grade at the building face and 2.4mt below grade at the property line/main sanitary pipe.

PART B- SPECIFICATIONS

- RESERVED

PART C – ARCHITECTURAL DRAWINGS

- RESERVED

PART D – MECHANICAL / ELECTRICAL DRAWINGS

- RESERVE

END OF ADDENDUM # 006