



**Addendum # 2**  
**Bid Opportunity: 26-7857-RFT - Kitchener**  
**Waterloo Collegiate and Vocational School**  
**Health and Physical Education Renovation**  
**Closing Date: Thursday, April 30, 2026 2:00 PM**

---

The following issued by the Board shall form part of the Bid / Proposal Solicitation document. The revisions and additions noted herein along with any attachments shall be read in conjunction with all other related documents. This Addendum shall, take precedence over the previously issued documents where differences occur. Receipt of this addendum must be acknowledged in the Bidding System, bids&tenders.

If you have already submitted a Bid / Proposal, it will be automatically withdrawn as a result of this addendum. You must resubmit the Bid / Proposal acknowledging all addenda and revising your Bid / Proposal to comply with all addenda.

**Question 1:**

Is the window between door V11 and V12 also aluminum?

**Answer 1: Yes, refer to Addendum 001.**

**Question 2:**

Confirm what low-e is required, bot LoE-366 and Solarban 60 are mentioned in the specs.

**Answer 2: Refer to spec section 08 80 50 2.3**

**Question 3:**

Are both inboard and outboard pane laminated?

**Answer 3: Yes, refer to spec section 08 80 50 2.4**

**Clarification/Revision by the Board**

1. Revision on Division 10, 10 51 13 Metal Lockers, 2.1 Acceptable Manufacturer

Subject to compliance with requirements specified in this Section [and as established by the Basis-of-Design Materials], manufacturers offering products that may be incorporated into the Work include the following:

- .1 Canadian Locker Company Ltd.
- .2 Dasco Storage Solutions.
- .3 General Storage Systems.
- .4 Mitchell Division 10 Ltd.

2. Revision on Division 08, 08 44 13 Glazed Aluminum Framing Systems, 2.1 Standards of Acceptance Systems Descriptions

Subject to compliance with requirements specified in this Section [and as established by the Basis-of-Design Materials], manufacturers offering products that may be incorporated into the Work include the following:

- .1 Kawneer
- .2 Alumicor
- .3 Windspec
- .4 Commercial

**END OF ADDENDUM**