



Addendum # 2

Bid Opportunity: 26-7850-RFT - Exterior and 347V
Interior LED Lighting Upgrades at 4 Schools
Closing Date: Wednesday, May 13, 2026 2:00 PM

The following issued by the Board shall form part of the Bid / Proposal Solicitation document. The revisions and additions noted herein along with any attachments shall be read in conjunction with all other related documents. This Addendum shall, take precedence over the previously issued documents where differences occur. Receipt of this addendum must be acknowledged in the Bidding System, bids&tenders.

If you have already submitted a Bid / Proposal, it will be automatically withdrawn as a result of this addendum. You must resubmit the Bid / Proposal acknowledging all addenda and revising your Bid / Proposal to comply with all addenda.

Question 1:

Can you provide the floor construction details for coring notes at Sunnyside PS

Answer 1:

Sunnyside PS is floor construction is believed to be a composite steel deck.

Question 2:

Are you able to quantify ceiling tile replacements required

Answer 2:

The contractor shall replace damaged ceiling tiles as part of this work. The contractor shall determine quantity to be carried as part of the work. Where ceiling tile replacement is identified on the drawings, include for the necessary quantity to suit the design drawings.

Question 3:

At Baden school fixtures Type BB and CC are currently missing from the Lighting Schedule. Please confirm these fixtures.

Answer 3:

Revise 3x fixture type 'CC' to fixture type 'C' (Drawing E301).
Revise 1x fixture type 'BB' to fixture type 'B' (Drawing E301).

Question 4:

We have received confirmation from the distributor that the specified T8 lamp model has been discontinued and is no longer available for quotation. Could you please confirm whether the school board intends to issue an addendum to address this discontinued item and provide approved alternative specifications?

Answer 4:

Four alternative products are listed within the lighting fixture schedules. Contractor shall provide a product as listed within the lighting fixture schedules.

END OF ADDENDUM